


Appendix A. Flow Analysis Documents

MERIT SYRINGE FLOW ANALYSIS

C:\Documents and Settings\vbg.ORNL\My Documents\My Files\MERIT\Hg System\Fathom\MERIT Design R1.fth
Base Scenario



MERIT SYRINGE FLOW ANALYSIS

Hg Syringe Model
Reference 25 Apr 2006

MERIT SYRINGE FLOW ANALYSIS

Execution Time= 0.08 seconds
Total Number Of Head/Pressure Iterations= 0
Total Number Of Flow Iterations= 2
Total Number Of Temperature Iterations= 2
Number Of Pipes= 11
Number Of Junctions= 12
Matrix Method= Gaussian Elimination

Pressure/Head Tolerance= 0.0001 relative change
Flow Rate Tolerance= 0.0001 relative change
Temperature Tolerance= 0.0001 relative change
Flow Relaxation= (Automatic)
Pressure Relaxation= (Automatic)

Heat Transfer with Energy Balance
Fluid Database: AFT Standard
Fluid: Mercury
Max Fluid Temperature Data= 500 deg. F
Min Fluid Temperature Data= 0 deg. F
Default Temperature= 80 deg. F
Default Density= 846.7027 lbm/ft3
Default Viscosity= 3.69638 lbm/hr-ft
Default Vapor Pressure= 1.0636E-04 atm
Viscosity Model= Newtonian

Atmospheric Pressure= 1 atm
Gravitational Acceleration= 1 g
Turbulent Flow Above Reynolds Number= 4000
Laminar Flow Below Reynolds Number= 2300

MERIT SYRINGE FLOW ANALYSIS

WARNING HGL, EGL and head loss results may not be meaningful for variable density systems.

MERIT SYRINGE FLOW ANALYSIS

Pipe Output Table

| Pipe | Name | Pipe Nominal Size | Vol. Flow (liter/sec) | Length (cm) | Flow Area (cm ²) | Velocity (cm/sec) | Reynolds No. | fL/ D + K | P Stag. In (barG) | P Stag. Out (barG) | dP Stag. Total (bar) | P Static In (barG) | P Static Out (barG) | dP Static Total (bar) |
|------|-------------------------|-------------------------|-----------------------------|----------------|------------------------------------|----------------------|-----------------|--------------|-------------------------|--------------------------|----------------------------|--------------------------|---------------------------|-----------------------------|
| 1 | Hg Cylinder | 10 inch | 1.57 | 38.10 | 508.736 | 3.09 | 6.86E+04 | 0.0296 | 42.6 | 42.6 | 0.00000191 | 42.63 | 4.26E+01 | 0.00000191 |
| 2 | Cylinder Discharge Pipe | 1 inch | 1.57 | 3.17 | 5.576 | 281.63 | 6.56E+05 | 0.0213 | 42.4 | 42.4 | 0.01147854 | 41.83 | 4.18E+01 | 0.01147854 |
| 3 | Cylinder Discharge Pipe | 1 inch | 1.57 | 11.58 | 5.576 | 281.63 | 6.56E+05 | 0.0778 | 42.1 | 42.0 | 0.19407322 | 41.61 | 4.14E+01 | 0.19407322 |
| 4 | Cylinder Discharge Pipe | 1 inch | 1.57 | 14.22 | 5.576 | 281.63 | 6.56E+05 | 0.0955 | 41.8 | 41.5 | 0.23406301 | 41.23 | 4.10E+01 | 0.23406301 |
| 5 | Hose Inlet | 1 inch | 1.57 | 3.05 | 5.576 | 281.63 | 6.56E+05 | 0.0205 | 41.3 | 41.3 | 0.01101942 | 40.76 | 4.07E+01 | 0.01101942 |
| 6 | Flex Hose | 1 inch | 1.57 | 34.29 | 6.098 | 257.53 | 6.27E+05 | 0.2186 | 41.3 | 41.2 | 0.09844139 | 40.83 | 4.07E+01 | 0.09844139 |
| 7 | Hg Supply Piping | 3/4 inch | 1.57 | 4.42 | 3.960 | 396.58 | 7.78E+05 | 0.0362 | 40.9 | 40.9 | 0.03869272 | 39.87 | 3.98E+01 | 0.03869272 |
| 8 | Hg Supply Piping | 3/4 inch | 1.57 | 4.39 | 3.960 | 396.58 | 7.78E+05 | 0.0360 | 40.7 | 40.7 | 0.03847035 | 39.66 | 3.96E+01 | 0.03847035 |
| 9 | Hg Supply Straight | 3/4 inch | 1.57 | 130.30 | 3.960 | 396.58 | 7.78E+05 | 1.0684 | 40.5 | 39.4 | 1.14076805 | 39.44 | 3.83E+01 | 1.14076805 |
| 10 | Reducer Inlet | 3/4 inch | 1.57 | 9.14 | 3.960 | 396.58 | 7.78E+05 | 0.0750 | 38.9 | 38.8 | 0.08005390 | 37.83 | 3.77E+01 | 0.08005390 |
| 11 | Nozzle tubing | 1/2 inch | 1.57 | 3.81 | 0.694 | 2,263.76 | 1.86E+06 | 0.0559 | 36.7 | 34.8 | 1.94466186 | 1.94 | 5.26E-07 | 1.94466186 |


MERIT SYRINGE FLOW ANALYSIS

All Junction Table

| Jct | Name | Junction Type | Elevation Inlet (cm) | Loss Factor (K) | dH (cm) | P Stag. In (barG) | P Stag. Out (barG) | dP Stag. Total (bar) | P Static In (barG) | P Static Out (barG) | dP Static Total (bar) | T Inlet (deg. C) |
|-----|------------------------|-------------------|----------------------|-----------------|---------|-------------------|--------------------|----------------------|--------------------|---------------------|-----------------------|------------------|
| 1 | Syringe Piston | Assigned Flow | 0.0 | 0.00000 | 0.000 | 42.6 | 42.6 | 0.00000 | 42.63325119 | 42.63325119 | 0.0000 | 20.0 |
| 2 | Area Change | Area Change | 0.0 | 4,128.12207 | 20.054 | 42.6 | 42.4 | 0.26703 | 42.63324356 | 41.82778549 | 0.8055 | 20.1 |
| 3 | Horizontal to Vertical | Bend | 0.0 | 0.33841 | 13.685 | 42.4 | 42.1 | 0.20760 | 41.81630707 | 41.60871124 | 0.2076 | 20.1 |
| 4 | Angle Bend | Bend | 13.3 | 0.27347 | 11.059 | 42.0 | 41.8 | 0.18785 | 41.41463470 | 41.22678375 | 0.1879 | 20.1 |
| 5 | Vertical to Horizontal | Bend | 30.1 | 0.33841 | 13.686 | 41.5 | 41.3 | 0.23297 | 40.99272156 | 40.75975037 | 0.2330 | 20.1 |
| 6 | Pipe to Flex | Area Change | 33.9 | 0.00733 | 0.296 | 41.3 | 41.3 | 0.00395 | 40.74873352 | 40.83303070 | -0.0843 | 20.1 |
| 7 | Flex to Tubing | Area Change | 33.9 | 0.54029 | 18.269 | 41.2 | 40.9 | 0.24327 | 40.73458862 | 39.87381363 | 0.8608 | 20.1 |
| 8 | Piping Elbow 1 | Bend | 33.9 | 0.16817 | 13.485 | 40.9 | 40.7 | 0.17957 | 39.83512497 | 39.65555573 | 0.1796 | 20.1 |
| 9 | Piping Elbow 2 | Bend | 33.9 | 0.16817 | 13.485 | 40.7 | 40.5 | 0.17957 | 39.61708832 | 39.43751907 | 0.1796 | 20.1 |
| 10 | 180 bend | Bend | 33.9 | 0.50572 | 40.553 | 39.4 | 38.9 | 0.46727 | 38.29675293 | 37.82947540 | 0.4673 | 20.1 |
| 11 | Tubing Reduction | Area Change | 28.4 | 1.94864 | 156.258 | 38.8 | 36.7 | 2.08069 | 37.74942017 | 1.94466197 | 35.8048 | 20.1 |
| 12 | Assigned Pressure | Assigned Pressure | 28.4 | 0.00000 | 0.000 | 34.8 | 34.8 | 0.00000 | -0.00000184 | -0.00000184 | 0.0000 | 23.9 |

MERIT SYRINGE FLOW ANALYSIS

C:\Documents and Settings\vbg.ORNLM\My Documents\My Files\MERIT\Hg System\Fathom\MERIT Design R1.fth
Base Scenario



Appendix B. Syringe Pump Documents

**Job A-6981 Brookhaven National Labs
Design Calculations**

Given:

Hg cylinder is 10" bore
Flow rate required: 25 gpm
Induced pressure required: 1500 psi
Drive cylinders are (2) 6" bore x 2.5" rods
Proportional valve = 4WREE10E50
Pump = 45cc piston pump, pressure comp.

Calculations

Area of 10" bore = 78.54 in²

Velocity to produce 25 gpm nominal

$25(231)/78.54 = 73.53 \text{ in/min} = 1.2255 \text{ in/sec}$

Velocity to produce 30 gpm max

$30(1.2255)/25 = 1.4706 \text{ in/sec}$

Drive cylinder net area = 23.37 in²

Area ration = 1.21:1

Flow req'd for 1.2255 in/sec, Q =

$Q = 1.2255(23.37)(60/231) = 7.44 \text{ gpm}$

Total Q = 14.88 gpm (for 25 gpm Hg)

Return flow rate from drive cylinders

$Q_{out} = 1.21 (14.88) = 18 \text{ gpm}$

For 30 gpm Hg, $Q = 14.88 (30/25) = 17.86 \text{ gpm}$

NOTE: Potential for 45cc pump at 1480 rpm and
95% vol eff = 16.7 gpm. This give ability to induce only
 $Vel = 16.7\text{gpm} * 231\text{in}^3/\text{gal} / 60 \text{ s/min} / 23.37 \text{ in}^2 / 2\text{cyl}$
 $Vel = 1.3756 \text{ in/sec}$

$QHg @ 1.3756 \text{ in/sec} = 1.3756 (78.54 \text{ in}^2) (60/231)$

Q Hgmax = 28.06 gpm Hg when pump @ 1480 rpm

Calculate system pressure req'd to induce 1500 psi Hg

Force @ Hg cyl = 78.54 in² * 1500 psi = 117,810 lbs

Drive cyl net area = 23.37 in² x 2 cyl = 46.74 in²

Pressure @ drive cyl = 117,810 lbs / 46.74 in² =

P = 2520 psi required at cylinders.

Estimate pressure drops at about 21 gpm:

Prop valve @ 100% open:

PSI
400

| | |
|--------------------|----|
| Hoses - rod side | 25 |
| Hoses - blind side | 50 |
| Filter | 15 |
| Misc fittings | 30 |

| | |
|---|-----|
| Total estimated pressure drop at velocity = 520 psi | 520 |
|---|-----|

System pressure as set at pump compensator

$P_{sys} = 2520 \text{ psi @ cyl} + 520 \text{ psi flow losses}$

| |
|------------------------------|
| $P_{sys} = 3039 \text{ psi}$ |
|------------------------------|

Calculate drive power required

$HP = 3039 \text{ psi} * 14.88 \text{ gpm} / (1714 * .85\text{eff})$

| |
|--|
| $HP = 31.03 \text{ HP @ } 25 \text{ gpm Hg flow (peak)}$ |
|--|

$HP = 3039 \text{ psi} * 16.7 \text{ gpm} / (1714 * .85 \text{ eff})$


| |
|---|
| $HP = 34.8 \text{ HP @ } 28 \text{ gpm Hg flow (peak)}$ |
|---|

Determine Peak power draw in USA @ 1750 rpm

Pump flow potential 20.8 gpm at 100% vol eff, 1750 rpm

| |
|---|
| $HP = 20.8 (3039) / (1714 * .95 \text{ eff mech}) = 38.8 \text{ HP peak}$ |
|---|

Note, this would be 129% of rated 30 HP motor



AT CONCLUSION OF TESTS USING TAP WATER, FLUSH CYLINDER WITH DISTILLED WATER.

- NOTES:
 1. DESIGNED FOR USE WITH QUAKER QUINTOLUBRIC 888.
 2. PUMP FLOW: 19.8 GPM @ 1750 RPM, 16.7 GPM @ 1480 RPM.

BALL VALVES ITEM 25 (2 PLACES) ARE NORMALLY CLOSED. USE FOR NITROGEN PURGE FOR LONG-TERM STORAGE.

| | | | | | |
|---------------|---|--|--|---------|------------------------|
| JOB #: A-6981 | ALL TECHNICAL DATA DISCLOSED HEREIN IS THE PROPERTY OF AIRLINE AND SHALL NOT BE USED BY OTHERS FOR MANUFACTURE, PROCUREMENT, OR DISCLOSURE WITHOUT THE WRITTEN PERMISSION OF THE OWNER. | |  Airline Machinery Group 1-95 and Street Road, Bensalem, PA. 19020 (215) 638-4700 | | |
| | TOLERANCES ON ALL DIMENSIONS, EXCEPT NOTED: DECIMALS: .X ± 0.03" FRACTIONS ± 1/16 .XX ± 0.01" ANGULAR ± 0.5° .XXX ± 0.005" FINISH: 125 | | TITLE: BROOKHAVEN NATIONAL LABS Hg JET HYDRAULIC UNIT HYDRAULIC SCHEMATIC | | |
| | ⊥ PERPENDICULARITY — STRAIGHTNESS ↗ RUNOUT ▭ FLATNESS | ⊕ CONCENTRICITY ⊕ TRUE POSITION PARALLELISM ⊙ PROJECTION | DWG. #: 6981001H | SIZE: C | SCALE: NA |
| | | | DATE: 11/16/05 | BY: JB | REV.: SHEET: 1 OF 1 |

HANNA CYLINDERS

HIGH PRESSURE HYDRAULIC TEST REPORT

USE ENGINEERING TEST STANDARD #ES3207
(UNLESS OTHERWISE INDICATED).

| | | | | |
|------------------------------|---------------------|---------------------|------------------------|---------------------------|
| SERIAL # <i>K11422704</i> | MODEL <i>ME5</i> | BORE <i>6.00</i> | STROKE <i>15.00</i> | JOB # <i>114227004</i> |
|------------------------------|---------------------|---------------------|------------------------|---------------------------|

DIMENSIONS

VERIFIED PER *X* DRAWING # *706-40342-030 REV D*
a OTHER (Describe) *DETAIL*

FASTENERS

| | | |
|----------------------|------------------------------|-------|
| <i>TIE ROD</i> | TORQUED TO <u><i>300</i></u> | FT-LB |
| <i>S.H.C.S GLAND</i> | TORQUED TO <u><i>18</i></u> | FT-LB |
| | TORQUED TO _____ | FT-LB |

TESTING PRESSURE

| | |
|----------------------|---|
| HYD. PSI | BREAK-AWAY PRESSURE: PASS <u><i>X</i></u> FAIL _____ |
| _____ 500 | |
| _____ 1000 | |
| _____ 1200 | |
| _____ 1500 | |
| _____ 1800 | |
| _____ 2200 | |
| <u><i>X</i></u> 3000 | |
| <u><i>X</i></u> 4500 | |
| _____ 5000 | |

LEAKAGE TESTS

| | |
|-------------------------------|---------------------------------|
| EXTERNAL | INTERNAL BYPASS |
| <u><i>X</i></u> TUBE END SEAL | PASS <u><i>X</i></u> FAIL _____ |
| <u><i>X</i></u> ROD SEAL | |
| _____ SPECIAL PIPING | |
| _____ | |
| _____ | |
| _____ | |

REMARKS

TESTED BY: *Raul Lopez* DATE *3/9/06* APPROVED BY: *[Signature]* DATE *3/9/06*

HANNA CYLINDERS

HIGH PRESSURE HYDRAULIC TEST REPORT

USE ENGINEERING TEST STANDARD #ES3207
(UNLESS OTHERWISE INDICATED).

| | | | | |
|------------------------------|---------------------|---------------------|------------------------|---------------------------|
| SERIAL # <i>K11422703</i> | MODEL <i>ME5</i> | BORE <i>6.00</i> | STROKE <i>15.00</i> | JOB # <i>114227003</i> |
|------------------------------|---------------------|---------------------|------------------------|---------------------------|

DIMENSIONS

VERIFIED PER *X* DRAWING # *706-40342-031 REV C*
K OTHER (Describe) *DETAIL*

FASTENERS

| | | |
|---------------------|-----------------------|-------|
| <i>TIE ROD</i> | TORQUED TO <i>300</i> | FT-LB |
| <i>GLAND SCREWS</i> | TORQUED TO <i>18</i> | FT-LB |
| | TORQUED TO _____ | FT-LB |

TESTING PRESSURE

| | |
|--|--|
| HYD. PSI _____ 500 _____ 1000 _____ 1200 _____ 1500 _____ 1800 _____ 2200 <u><i>X</i></u> 3000 <u><i>K</i></u> 4500 _____ 5000 | BREAK-AWAY PRESSURE: PASS <u><i>X</i></u> FAIL _____ |
|--|--|


LEAKAGE TESTS

| | |
|--|---|
| <p style="text-align: center;">EXTERNAL</p> <u><i>K</i></u> TUBE END SEAL <u><i>K</i></u> ROD SEAL _____ SPECIAL PIPING _____ _____ | <p style="text-align: center;">INTERNAL BYPASS</p> PASS <u><i>K</i></u> FAIL _____ |
|--|---|

REMARKS

TESTED BY:

APPROVED BY:

Raul Lopez DATE *3/9/06*  DATE *3/9/06*

HANNA CYLINDERS

HIGH PRESSURE HYDRAULIC TEST REPORT

USE ENGINEERING TEST STANDARD #ES3207
(UNLESS OTHERWISE INDICATED).

| | | | | |
|-------------------------------|---------------------|--------------------|----------------------|---------------------------|
| SERIAL # K 11422705 | MODEL MS7 | BORE 10" | STROKE 15" | JOB # 114227005 |
|-------------------------------|---------------------|--------------------|----------------------|---------------------------|

DIMENSIONS

VERIFIED PER **K** DRAWING # **706-81637-000 REV E**
K OTHER (Describe) **DETAIL**

FASTENERS

| | | | |
|---------------------------|------------|-------------------|-------|
| <u>TIE RODS</u> | TORQUED TO | <u>500</u> | FT-LB |
| <u>GLAND SCREW</u> | TORQUED TO | <u>18</u> | FT-LB |
| | TORQUED TO | | FT-LB |

TESTING PRESSURE

| | |
|---|---|
| HYD. PSI _____ 500 _____ 1000 _____ 1200 _____ 1500 _____ 1800 <input checked="" type="checkbox"/> 2200 _____ 3000 _____ 4500 _____ 5000 | BREAK-AWAY PRESSURE: PASS <u>X</u> FAIL _____ |
|---|---|

LEAKAGE TESTS

| | |
|---|---|
| EXTERNAL <input checked="" type="checkbox"/> TUBE END SEAL <input checked="" type="checkbox"/> ROD SEAL _____ SPECIAL PIPING _____ _____ _____ | INTERNAL BYPASS PASS <u>X</u> FAIL _____ |
|---|---|

REMARKS

TESTED BY:

APPROVED BY:

PAUL LOPEZ DATE **3/8/06** **[Signature]** DATE **3/8/06**

Appendix C. Primary Containment Documents



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Optical Viewport Stresses in Pressure Testing

SHEET 1 OF 1

DRAWING NO 203-HJT-0630

CALCULATION BY V. Graves

DATE 12 Apr 2006

The primary containment system may be run under vacuum conditions or may be pressurized during leak testing operations. This calculation checks the integrity of the sapphire viewports under 1atm pressure. Calculations based on Roark's Formulas for Stress and Strain, 6th edition, Flat Plates case 10b.

| | |
|---|--------------------------------------|
| $\nu := 0.29$ | Poissons ratio |
| $E := 50 \cdot 10^6 \text{ psi}$ | modulus of elasticity |
| $S_y := 40000 \text{ psi}$ | tensile yield strength sapphire |
| $a := 1.5 \text{ in}$ | outer radius of unsupported viewport |
| $t := 0.236 \text{ in}$ | viewport thickness |
| $q := 15 \text{ psi}$ | pressure loading |
| $D := \frac{E \cdot t^3}{12 \cdot (1 - \nu^2)}$ | plate constant |
| $y_c := \frac{-q \cdot a^4}{64D}$ | deflection at center |
| $y_c = -1.984 \times 10^{-5} \text{ in}$ | |
| $M_c := \frac{q \cdot a^2 \cdot (1 + \nu)}{16}$ | moment at center |
| $\sigma := \frac{6M_c}{t^2}$ | stress at center |
| $\sigma = 293.137 \text{ psi}$ | |
| $FS := \frac{S_y}{\sigma}$ | safety factor for pressure loading |
| $FS = 136.455$ | |



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Nozzle Offsets

SHEET 1 OF 1

DRAWING NO 203-HJT-0001

CALCULATION BY Van Graves

DATE 26 Jan 2006

Problem is to calculate the vertical offset of the nozzle given a Z starting position relative to the center of the magnet so that the jet path intersects the beam and magnet axes simultaneously.

From the equations for projectile motion we have

$$x = v_0 \cos \theta \cdot t$$

$$y = v_0 \sin \theta \cdot t - \frac{1}{2} g t^2$$

$$y = f(x) = x \tan \theta - \frac{g}{2v_0^2 \cos^2 \theta} x^2$$

$$\frac{dy}{dx} = \tan \theta - \frac{g}{v_0^2 \cos^2 \theta} x$$

With regards to these equations, coordinate system is at the center of the jet starting position. All angular references are with respect to the ground (relative to the beam for our experiment).

An approximation is made that for small angles, $\cos^2 \theta \sim 1$, so we can determine a starting angle which will provide a desired slope at a specified distance.

$$x := 45\text{cm} \quad dydx := -0.033 \quad v_0 := 2000 \frac{\text{cm}}{\text{s}}$$

$$\theta := \text{atan} \left(dydx + \frac{g}{v_0^2} \cdot x \right) \quad \theta = -0.022$$

Now calculate the vertical drop of the jet after traveling 45cm horizontally.

$$y := \tan(\theta) \cdot x - \frac{g}{2 \cdot v_0^2 \cdot \cos(\theta)^2} \cdot x^2 \quad y = -1.237 \text{ cm}$$

The jet falls 1.24 cm over the distance, so the starting position of the nozzle should compensate for this fall. So for a horizontal starting position of Z=-45cm, the center of the nozzle should be 1.24cm above the beam and have a starting angle of -22mrad relative to the beam. Note this calculation does not include deflections caused by MHD effects.



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Nozzle Flange Moment


SHEET 1 OF 2

DRAWING NO 203-HJT-0620

CALCULATION BY V.B. Graves

DATE 26 April 2006

Calculate the moment imparted by the flowing Hg on the flange mounting bolts. The moment is calculated at the nozzle flange face. The inlet pressure was obtained using AFT Fathom (incorporates frictional losses and pressure drops in the actual piping). Exit pressure of the nozzle is atmospheric (zero gage pressure).



$$\rho := 13540 \frac{\text{kg}}{\text{m}^3} \quad \text{Fluid density} \quad Q := 1.57 \frac{\text{liter}}{\text{s}} \quad \text{Flow rate}$$

$$\text{mflow} := \rho \cdot Q \quad \text{mflow} = 21.258 \frac{\text{kg}}{\text{s}} \quad \text{mass flow rate}$$

$$d_1 := 0.884 \text{in} \quad d_2 := 0.4 \text{in} \quad \text{Inlet \& exit diameters}$$

$$A_1 := \frac{\pi}{4} d_1^2 \quad A_2 := \frac{\pi}{4} d_2^2 \quad \text{Inlet \& exit flow areas}$$

$$A_1 = 3.96 \text{cm}^2 \quad A_2 = 0.811 \text{cm}^2$$

$$V_1 := \frac{Q}{A_1} \quad V_2 := \frac{Q}{A_2} \quad \text{Inlet \& exit velocities}$$

$$V_1 = 3.965 \frac{\text{m}}{\text{s}} \quad V_2 = 19.365 \frac{\text{m}}{\text{s}}$$

$$p_1 \text{ is obtained from AFT Fathom: } p_1 := 555 \text{psi} \quad p_1 = 3.827 \times 10^6 \text{Pa}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Nozzle Flange Moment

SHEET 2 OF 2

DRAWING NO 203-HJT-0620

CALCULATION BY V.B. Graves

DATE 26 April 2006

For an inertial, non-deformable control volume with 1-dimensional inlets & outlets, conservation of angular momentum states that

$$\frac{d}{dt} \mathbf{H}_o = \sum \mathbf{M}_o = \sum (\mathbf{r} \times \mathbf{F})_o = \sum (\mathbf{r} \times \mathbf{V})_{out} \dot{m}_{out} - \sum (\mathbf{r} \times \mathbf{V})_{in} \dot{m}_{in}$$

$$\mathbf{T}_o + \mathbf{r}_1 \times (-p_1 A_1 \mathbf{n}_1) = (\mathbf{r}_1 \times \mathbf{V}_1)(-\dot{m}_{in})$$

$$T_o - p_1 A_1 r_1 = +\dot{m} r_1 V_1$$

$$T_o = r_1 (p_1 A_1 + \dot{m} V_1)$$

$$r_1 := 3 \text{ in} \quad T_o := r_1 \cdot (p_1 A_1 + \text{mflow} \cdot V_1)$$

$$T_o = 89.9 \text{ ft}\cdot\text{lbf}$$

$$T_o = 121.9 \text{ N}\cdot\text{m}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Nozzle Flange Axial Force


SHEET 1 OF 2

DRAWING NO 203-HJT-0620

CALCULATION BY V.B. Graves

DATE 26 April 2006

Calculate the forces imparted by the flowing Hg on the flange mounting bolts. The force is calculated at the nozzle. A reference calculation of the inlet pressure is made using Bernoulli's equation, but the inlet pressure calculated using AFT Fathom (incorporates frictional losses and pressure drops in the actual piping) is used for subsequent force calculations. Exit pressure of the nozzle is atmospheric (zero gage pressure).



$$\rho := 13540 \frac{\text{kg}}{\text{m}^3} \quad \text{Fluid density} \quad Q := 1.57 \frac{\text{liter}}{\text{s}} \quad \text{Flow rate}$$

$$\text{mass} := \rho \cdot Q \quad \text{mass} = 21.258 \frac{\text{kg}}{\text{s}} \quad \text{mass flow rate}$$

$$d_1 := 0.884 \text{in} \quad d_2 := 0.4 \text{in} \quad \text{Inlet \& exit diameters}$$

$$A_1 := \frac{\pi}{4} d_1^2 \quad A_2 := \frac{\pi}{4} d_2^2 \quad \text{Inlet \& exit flow areas}$$

$$A_1 = 3.96 \text{cm}^2 \quad A_2 = 0.811 \text{cm}^2$$

$$V_1 := \frac{Q}{A_1} \quad V_2 := \frac{Q}{A_2} \quad \text{Inlet \& exit velocities}$$

$$V_1 = 3.965 \frac{\text{m}}{\text{s}} \quad V_2 = 19.365 \frac{\text{m}}{\text{s}}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Nozzle Flange Axial Force

SHEET 2 OF 2

DRAWING NO 203-HJT-0620

CALCULATION BY V.B. Graves

DATE 26 April 2006

Reference pressure at 1 is given by Bernoulli's equation:

$$p_{1\text{ref}} := \frac{1}{2} \rho \cdot (V_2^2 - V_1^2) \quad p_{1\text{ref}} = 353 \text{ psi} \quad p_{1\text{ref}} = 2.43 \times 10^6 \text{ Pa}$$

A more accurate value of p1 is obtained from AFT Fathom: $p_1 := 555 \text{ psi}$ $p_1 = 3.827 \times 10^6 \text{ Pa}$

A control volume analysis provides the resultant force

$$\sum \mathbf{F}_x = p_1 A_1 - F = \dot{m}(\mathbf{V}_2 - \mathbf{V}_1) = \dot{m}(-V_2 - V_1)$$

$$F = p_1 A_1 + \dot{m}(V_2 + V_1)$$

$$p_1 \cdot A_1 = 341 \text{ lbf} \quad \text{mass} \cdot (V_2 + V_1) = 111 \text{ lbf}$$

$$F := p_1 \cdot A_1 + \text{mass} \cdot (V_2 + V_1) \quad F = 452 \text{ lbf} \quad F = 2011 \text{ N}$$

The nozzle flange is attached with ten SS 18-8 #10-24 socket head cap screws. If the system were completely rigid, the stress seen in the screws due to the axial force would be

$$A_t := 0.0175 \text{ in}^2 \quad \text{shcs thread stress area}$$

$$\sigma_y := 70000 \text{ psi} \quad \text{yield strength}$$

$$\sigma_{\text{act}} := \frac{F}{10 A_t} \quad \sigma_{\text{act}} = 2.584 \times 10^3 \text{ psi}$$

$$\text{FS} := \frac{\sigma_y}{\sigma_{\text{act}}} \quad \text{FS} = 27.094 \quad \text{Safety Factor}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Supply Line Pressure Rating

SHEET 1 OF 1

DRAWING NO 203-HJT-0620 Item 2

CALCULATION BY V.B. Graves

DATE 28 March 2006

This calculation supports the design of the Hg supply feedline that is between the flexible hose and the reducer. The feedline is being designed and fabricated to ASME VIII standards. Material is Grade 2 Titanium welded pipe. Nominal design is 3/4" SCH10 pipe.

$D := 1.05\text{in}$ nominal OD for 3/4" pipe
 $t := 0.083\text{in}$ wall thickness for Sch 10
 $P := 1500\text{psi}$ design pressure
 $S_{\text{max}} := 12100\text{psi}$ max allowable stress per ASME VIII Table 1B
 $E := 1$ joint efficiency per ASME VIII UW-12
 $R_{\text{in}} := \frac{D - 2t}{2}$ inner radius

Circumferential Stress (Longitudinal Joints)

$$t_{\text{min1}} := \frac{P \cdot R}{S \cdot E - 0.6P} \quad t_{\text{min1}} = 0.059 \text{ in} \quad t_{\text{min1}} = 1.504 \text{ mm}$$

$$P_{\text{max1}} := \frac{S \cdot E \cdot t}{R + 0.6t} \quad P_{\text{max1}} = 2042 \text{ psi} \quad P_{\text{max1}} = 14.08 \times 10^6 \text{ Pa}$$

Longitudinal Stress (Circumferential Joints)

$$t_{\text{min2}} := \frac{P \cdot R}{2S \cdot E + 0.4P} \quad t_{\text{min2}} = 0.027 \text{ in} \quad t_{\text{min2}} = 0.679 \text{ mm}$$

$$P_{\text{max2}} := \frac{2S \cdot E \cdot t}{R - 0.4t} \quad P_{\text{max2}} = 4913 \text{ psi} \quad P_{\text{max2}} = 33.877 \times 10^6 \text{ Pa}$$

In both stress calculations, the design exceeds minimum thickness and the design pressure is below the maximum allowable.



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Nozzle Pressure Rating

SHEET 1 OF 1

DRAWING NO 203-HJT-0620 Item 4

CALCULATION BY V.B. Graves

DATE 28 March 2006

This calculation supports the design of the Hg nozzle tube. The tube is being designed and fabricated to ASME VIII standards. Material is Grade 2 Titanium 0.5" seamless welded tubing.

D := 0.5in nominal OD
 t := 0.035in wall thickness
 P := 1500psi design pressure
 S_{\max} := 14300psi max allowable stress per ASME VIII Table 1B
 E := 1 joint efficiency per ASME VIII UW-12
 R_{in} := $\frac{D - 2t}{2}$ inner radius

Circumferential Stress (Longitudinal Joints)

$$t_{\min 1} := \frac{P \cdot R}{S \cdot E - 0.6P} \quad t_{\min 1} = 0.024 \text{ in} \quad t_{\min 1} = 0.611 \text{ mm}$$

$$P_{\max 1} := \frac{S \cdot E \cdot t}{R + 0.6t} \quad P_{\max 1} = 2121 \text{ psi} \quad P_{\max 1} = 14.622 \times 10^6 \text{ Pa}$$

Longitudinal Stress (Circumferential Joints)

$$t_{\min 2} := \frac{P \cdot R}{2S \cdot E + 0.4 \cdot P} \quad t_{\min 2} = 0.011 \text{ in} \quad t_{\min 2} = 0.281 \text{ mm}$$

$$P_{\max 2} := \frac{2S \cdot E \cdot t}{R - 0.4 \cdot t} \quad P_{\max 2} = 4980 \text{ psi} \quad P_{\max 2} = 34.337 \times 10^6 \text{ Pa}$$

In both stress calculations, the design exceeds minimum thickness and the design pressure is below the maximum allowable.



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Supply Line Pressure Rating

SHEET 1 OF 2

DRAWING NO 203-HJT-0670, -0680

CALCULATION BY V.B. Graves

DATE 20 April 2006

This calculation supports the design of the piping that acts as the inlet and outlet from the Hg cylinder. These lines are being designed and fabricated to ASME VIII standards. Material is 3/4" and 1" SCH40 SS304L welded pipe.

| | | |
|-------------------------------|-------------------------------|---|
| $D_1 := 1.05\text{in}$ | $D_2 := 1.315\text{in}$ | nominal OD for 3/4" & 1" pipe |
| $t_1 := 0.113\text{in}$ | $t_2 := 0.133\text{in}$ | wall thickness for 3/4" & 1" Sch 40 |
| $P := 1500\text{psi}$ | | design pressure |
| $S := 14200\text{psi}$ | | max allowable stress per ASME VIII Table 1A |
| $E := 1$ | | joint efficiency per ASME VIII UW-12 |
| $R_1 := \frac{D_1 - 2t_1}{2}$ | $R_2 := \frac{D_2 - 2t_2}{2}$ | inner radii |

Circumferential Stress (Longitudinal Joints) 3/4" pipe

| | | |
|--|--------------------------------|---|
| $t_{\min 1} := \frac{P \cdot R_1}{S \cdot E - 0.6P}$ | $t_{\min 1} = 0.046\text{ in}$ | $t_{\min 1} = 1.18\text{ mm}$ |
| $P_{\max 1} := \frac{S \cdot E \cdot t_1}{R_1 + 0.6t_1}$ | $P_{\max 1} = 3344\text{ psi}$ | $P_{\max 1} = 23.058 \times 10^6\text{ Pa}$ |

Longitudinal Stress (Circumferential Joints) 3/4" pipe

| | | |
|---|--------------------------------|---|
| $t_{\min 2} := \frac{P \cdot R_1}{2S \cdot E + 0.4P}$ | $t_{\min 2} = 0.021\text{ in}$ | $t_{\min 2} = 0.541\text{ mm}$ |
| $P_{\max 2} := \frac{2S \cdot E \cdot t_1}{R_1 - 0.4t_1}$ | $P_{\max 2} = 8749\text{ psi}$ | $P_{\max 2} = 60.323 \times 10^6\text{ Pa}$ |



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Supply Line Pressure Rating
DRAWING NO 203-HJT-0670, -0680
CALCULATION BY V.B. Graves

SHEET 2 OF 2

DATE 20 April 2006

Circumferential Stress (Longitudinal Joints) 1" pipe

$$t_{\min 3} := \frac{P \cdot R_2}{S \cdot E - 0.6P} \quad t_{\min 3} = 0.059 \text{ in} \quad t_{\min 3} = 1.503 \text{ mm}$$

$$P_{\max 3} := \frac{S \cdot E \cdot t_2}{R_2 + 0.6t_2} \quad P_{\max 3} = 3125 \text{ psi} \quad P_{\max 3} = 21.548 \times 10^6 \text{ Pa}$$

Longitudinal Stress (Circumferential Joints) 1" pipe

$$t_{\min 4} := \frac{P \cdot R_2}{2S \cdot E + 0.4P} \quad t_{\min 4} = 0.027 \text{ in} \quad t_{\min 4} = 0.689 \text{ mm}$$

$$P_{\max 4} := \frac{2S \cdot E \cdot t_2}{R_2 - 0.4t_2} \quad P_{\max 4} = 8014 \text{ psi} \quad P_{\max 4} = 55.258 \times 10^6 \text{ Pa}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Deflector Forces

SHEET 1 OF 1

DRAWING NO 203-HJT-0616

CALCULATION BY V.B. Graves

DATE 5 Jan 2005

Calculate the force of the Hg jet on the deflector plate, which also serves as the downstream primary beam window. Material is Ti6Al4V.

$$\rho := 13540 \frac{\text{kg}}{\text{m}^3} \quad \rho = 845.275 \frac{\text{lb}}{\text{ft}^3}$$

$$d_{\text{nozzle}} := 1 \text{ cm} \quad A_{\text{jet}} := \frac{\pi}{4} \cdot d_{\text{nozzle}}^2 \quad A_{\text{jet}} = 0.785 \text{ cm}^2$$

$$V_{\text{jet}} := 20 \frac{\text{m}}{\text{s}} \quad Q := A_{\text{jet}} \cdot V_{\text{jet}} \quad Q = 1.571 \frac{\text{L}}{\text{s}} \quad Q = 24.898 \frac{\text{gal}}{\text{min}}$$

$$m_{\text{jet}} := \rho \cdot Q \quad m_{\text{jet}} = 21.269 \frac{\text{mass}}{\text{time}} \quad m_{\text{jet}} = 46.889 \frac{\text{lb}}{\text{s}}$$

Assume deflector is vertical and jet is horizontal to simplify calculation - very conservative assumption. Hg spray will be evenly distributed in all directions, so vertical component of resultant force will be cancelled.

$$R_x := m_{\text{jet}} \cdot V_{\text{jet}} \quad R_x = 425.372 \text{ N} \quad R_x = 95.627 \text{ lbf}$$

To calculate the minimum deflector thickness, assume force acts in center of deflector and that the ends are rigidly supported.

$$S_y := 120000 \text{ psi} \quad \text{tensile yield strength of Ti6AlV4}$$

$$\text{Plate dimensions:} \quad w := 2 \text{ in} \quad \text{len} := 6 \text{ in} \quad t := 2 \text{ mm} \quad c := \frac{t}{2}$$

$$\text{Moment of inertia:} \quad I := \frac{1}{12} \cdot w \cdot t^3$$

$$\text{Shear} \quad \tau := \frac{V}{A} = \frac{R_x}{2 \cdot w \cdot t} \quad \tau = 455.425 \text{ psi}$$

$$M := \frac{R_x \cdot \text{len}}{8} \quad \sigma_{\text{act}} := \frac{M \cdot c}{I} \quad \sigma_{\text{act}} = 3.47 \times 10^4 \text{ psi} \quad \text{FS} := \frac{S_y}{\sigma_{\text{act}}} \quad \text{FS} = 3.458$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Supply Piping Moment


SHEET 1 OF 2

DRAWING NO 203-HJT-0623

CALCULATION BY V.B. Graves

DATE 10 May 2006

Calculate the moment imparted by the flowing Hg on the first piping restraint, assuming rigid connection. The fluid pressures were obtained using AFT Fathom so as to incorporate frictional losses and pressure drops in the actual piping.



$$\rho := 13540 \frac{\text{kg}}{\text{m}^3} \quad \text{Fluid density} \quad Q := 1.57 \frac{\text{liter}}{\text{s}} \quad \text{Flow rate}$$

$$\text{mflow} := \rho \cdot Q \quad \text{mflow} = 21.258 \frac{\text{kg}}{\text{s}} \quad \text{mass flow rate}$$

$$d := 0.884 \text{in} \quad \text{Inlet \& exit diameters are equal}$$

$$A := \frac{\pi d^2}{4} \quad V := \frac{Q}{A} \quad V = 3.965 \frac{\text{m}}{\text{s}} \quad \text{Flow area \& velocity}$$

$$p_1 := 578 \text{psi} \quad p_1 = 3.985 \times 10^6 \text{Pa} \quad \text{pressures obtained from AFT Fathom}$$

$$p_2 := 572 \text{psi} \quad p_2 = 3.944 \times 10^6 \text{Pa}$$

$$r_1 := 1 \text{in} \quad r_2 := 2.25 \text{in} \quad \text{offsets}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Supply Piping Moment

SHEET 2 OF 2

DRAWING NO 203-HJT-0623

CALCULATION BY V.B. Graves

DATE 10 May 2006

For an inertial, non-deformable control volume with 1-dimensional inlets & outlets, conservation of angular momentum states that

$$\frac{d}{dt} \mathbf{H}_o = \sum \mathbf{M}_o = \sum (\mathbf{r} \times \mathbf{F})_o = \sum (\mathbf{r} \times \mathbf{V})_{out} \dot{m}_{out} - \sum (\mathbf{r} \times \mathbf{V})_{in} \dot{m}_{in}$$

$$\mathbf{T}_o + \mathbf{r}_1 \times (-p_1 A_1 \mathbf{n}_1) + \mathbf{r}_2 \times (-p_2 A_2 \mathbf{n}_2) = (\mathbf{r}_2 \times \mathbf{V}_2) (\dot{m}_{out}) - (\mathbf{r}_1 \times \mathbf{V}_1) (\dot{m}_{in})$$

$$T_o - r_1 p_1 A + r_2 p_2 A = \dot{m} V (r_2 - r_1)$$

$$T_o = \dot{m} V (r_2 - r_1) + A (r_1 p_1 - r_2 p_2)$$

$$T_o := \text{mflow} \cdot V \cdot (r_2 - r_1) + A \cdot (r_1 \cdot p_1 - r_2 \cdot p_2) \quad \text{mflow} \cdot V \cdot (r_2 - r_1) = 1.974 \text{ ft} \cdot \text{lb} \cdot \text{f}$$

$$A \cdot (r_1 \cdot p_1 - r_2 \cdot p_2) = -36.263 \text{ ft} \cdot \text{lb} \cdot \text{f}$$

$$T_o = -34.3 \text{ ft} \cdot \text{lb} \cdot \text{f} \quad T_o = -46.5 \text{ N} \cdot \text{m}$$

Stress Analysis of Hg Sump Tank - Hg Weight

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: Nov 15, 2005

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the Hg sump tank is performed. Loading condition is 800 lb applied to bottom of tank to simulate weight of 23 liters Hg. No loads on the side walls were simulated.

Areas representing the square supports on the tank bottom were restrained.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|---------------|--------------------------|------------|-------------------------|
| 1 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |
| 2 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |
| 3 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|--|
| Restraint-1 <sump tank hjt> | on 2 Face(s) fixed. |
| Description: | Tank bottom restrained where it contacts supports. |

| Load | | |
|--------------------------------------|---|--------------------|
| Force-1 <sump tank hjt> | on 1 Face(s) apply normal force 800 lb using uniform distribution | Sequential Loading |
| Description: | Weight of 23 liters Hg applied to | |

| | | |
|--|--------------|--|
| | bottom face. | |
|--|--------------|--|

4. Study Property

| Mesh Information | |
|-----------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.59061 in |
| Tolerance: | 0.029531 in |
| Quality: | High |
| Number of elements: | 17641 |
| Number of nodes: | 35493 |


| Solver Information | |
|--------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------------|--------------------------------------|----------------------------------|--|
| Plot1 | VON: von Mises stress | 1.52968 psi Node: 25974 | (7.50297 in, 0 in, -3.2 in) | 867.968 psi Node: 27866 | (- 9.71311 in, 0.125 in, 2.37814 in) |

sump tank hgt-HgWeight-Stress-Plot1

JPEG




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|------------|------------|
| Plot1 | URES: Resultant displacement | 0 in | (9.18681 | 0.00103167 | (1.34711e- |
| | | Node: | in, | in | 015 in, |

| | | | | | |
|--|--|-------|-------------------|----------------|---------------------|
| | | 24918 | 0 in, 3.95 in) | Node: 23190 | 9.75 in, -11 in) |
|--|--|-------|-------------------|----------------|---------------------|

sump tank hjt-HgWeight-Displacement-Plot1

JPEG




7. Design Check Results

sump tank hjt-HgWeight-Design Check-Plot1

JPEG

Model name: sump tank hjt
Study name: HgWeight
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 35



8. Conclusion

Analysis shows minimum safety factor > 30, so tank is considered structurally sound for this loading condition.

9. Appendix

Material name: AISI 304
Description:
Material Source: Library files
Material Library Name: cosmos materials
Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 2.7557e+007 | psi | Constant |
| Poisson's ratio | 0.29 | NA | Constant |
| Shear modulus | 1.0878e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in ³ | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 1e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.000214 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Stress Analysis of Hg Jet Chamber

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: May 19, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the Hg jet chamber is performed. The chamber may be tested prior to Hg loading either by a static pressure test or a vacuum rate-of-rise test. A static internal pressure of 1atm was simulated in this analysis. During operation there will be no interior pressure within the weldment.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|-----------------------|--------------------------|------------|-------------------------|
| 1 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |
| 2 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |
| 3 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |
| 4 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |
| 5 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |
| 6 | pri tube weldment hjt | AISI 304 | 44.7162 lb | 154.718 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|----------------------------|
| Restraint-1 <pri tube weldment hjt> | on 1 Face(s) fixed. |
| Description: | Exit end face held fixed. |

| Load | | |
|---|--|--------------------|
| Pressure-1 <pri tube weldment hjt> | on 10 Face(s) with Pressure 15 psi along direction normal to selected face | Sequential Loading |
| Description: | 15 psi on all internal surfaces. | |

4. Study Property

| Mesh Information | |
|-----------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.53695 in |
| Tolerance: | 0.026848 in |
| Quality: | High |
| Number of elements: | 14806 |
| Number of nodes: | 30039 |


| Solver Information | |
|--------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|---------|-----------|---------|-----------|
| Plot1 | VON: von Mises stress | 10.3982 | (1.25 in, | 20466.5 | (0.658211 |
| | | psi | -2.6625 | | psi |
| | | Node: | - | Node: | 2.21623 |
| | | 693 | 18.0992 | 5620 | in, |
| | | | in) | | 25.9439 |
| | | | | | in) |

pri tube weldment hjt-Pressure1atm-Stress-Plot1

JPEG




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-----------------------|--|-----------------------------------|---|
| Plot1 | URES: Resultant displacement | 0 in Node: 1440 | (-0.6875 in, 0.645291 in, 34 in) | 0.0023928 in Node: 16816 | (- 0.8125 in, 1.88444 in, 28.9516 in) |

pri tube weldment hjt-Pressure1atm-Displacement-Plot1


JPEG



7. Design Check Results

pri tube weldment hjt-Pressure1atm-Design Check-Plot1

JPEG



8. Conclusion

Analysis indicates minimum safety factor > 10 , so structure is considered structurally sound for the simulated loading condition.

9. Appendix

Material name: AISI 304

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 2.7557e+007 | psi | Constant |
| Poisson's ratio | 0.29 | NA | Constant |
| Shear modulus | 1.0878e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in ³ | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 1e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.000214 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Stress Analysis of Hg Supply Reducer

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: April 12, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the Hg flow reducer is performed. The design pressure of 1500 psi was applied to the interior surfaces of the reducer.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing

is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|-----------------------|--|--------------|--------------------------|
| 1 | hg supply reducer hjt | Titanium Ti-6Al-4V (Grade 5), Annealed | 0.0998634 lb | 0.623975 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|---|
| Restraint-1 <hg supply reducer hjt> | on 2 Face(s) fixed. |
| Description: | Outer diameter and face of exit end fixed as they would be welded to the nozzle flange. |

| Load | | |
|---|--|--------------------|
| Pressure-1 <hg supply reducer hjt> | on 3 Face(s) with Pressure 1500 psi along direction normal to selected face | Sequential Loading |
| Description: | Design pressure load. | |

4. Study Property

| Mesh Information | |
|-----------------------|--------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.085485 in |
| Tolerance: | 0.0042742 in |
| Quality: | High |
| Number of elements: | 7612 |
| Number of nodes: | 15263 |

| Solver Information | |
|--------------------|---|
| Quality: | High |
| Solver Type: | FFE |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |

5. Stress Results


| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|---------------------------------|---|----------------------------------|-----------------------------------|
| Plot1 | VON: von Mises stress | 2.56573 psi Node: 2509 | (0.375 in, -0.249301 in, 0.0186825 | 13665.3 psi Node: 14939 | (- 0.041552 in, 0.244426 |

| | | | | | |
|--|--|--|-----|--|-----------|
| | | | in) | | in, |
| | | | | | 0.0683738 |
| | | | | | in) |

hg supply reducer hjt-1500psi-Stress-Plot1

JPEG

Model name: hg supply reducer hjt
 Study name: 1500psi
 Plot type: Static nodal stress Plot1
 Deformation scale: 349.094




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-----------------|--|-----------------------------|---|
| Plot1 | URES: Resultant displacement | 0 in Node: 1 | (0.375 in, 0.216506 in, -0.125 in) | 0.00117264 in Node: 2032 | (-3.625 in, 0.41769 in, -0.144564 in) |

hg supply reducer hjt-1500psi-Displacement-Plot1

JPEG


Model name: hg supply reducer hjt
Study name: 1500psi
Plot type: Static displacement Plot1
Deformation scale: 349.034



7. Design Check Results

hg supply reducer hjt-1500psi-Design Check-Plot1

JPEG



8. Conclusion

The flow reducer should never actually encounter the full design pressure since the downstream pressure drop is due to the nozzle, which requires about 400 psi. With a minimum safety factor > 9 for the design case, the reducer is considered structurally safe

for the simulated loading condition.

9. Appendix

Material name: Titanium Ti-6Al-4V (Grade 5), Annealed

Description:

Material Source: Library files

Material Library Name: titanium

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 1.6505e+007 | psi | Constant |
| Elastic modulus | 1.6505e+007 | psi | Constant |
| Elastic modulus | 1.6505e+007 | psi | Constant |
| Poisson's ratio | 0.342 | NA | Constant |
| Poisson's ratio | 0.342 | NA | Constant |
| Poisson's ratio | 0.342 | NA | Constant |
| Shear modulus | 6.3817e+006 | psi | Constant |
| Shear modulus | 6.3817e+006 | psi | Constant |
| Shear modulus | 6.3817e+006 | psi | Constant |
| Mass density | 0.16004 | lb/in ³ | Constant |
| Tensile strength | 1.3779e+005 | psi | Constant |
| Compressive strength | 1.4069e+005 | psi | Constant |
| Yield strength | 1.2763e+005 | psi | Constant |
| Thermal expansion coefficient | 4.7778e-006 | /Fahrenheit | Constant |
| Thermal expansion coefficient | 4.7778e-006 | /Fahrenheit | Constant |
| Thermal expansion coefficient | 4.7778e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 8.9611e-005 | BTU/(in.s.F) | Constant |
| Thermal conductivity | 8.9611e-005 | BTU/(in.s.F) | Constant |
| Specific heat | 0.12573 | Btu/(lb.F) | Constant |

Stress Analysis of Hg Sump Tank - Internal Pressure

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: Nov 15, 2005

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the Hg sump tank is performed. Loading condition is 1atm internal pressure applied to bottom and wall of tank to simulate leak check operation.

Areas representing the square supports on the tank bottom were restrained.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|---------------|--------------------------|------------|-------------------------|
| 1 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |
| 2 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |
| 3 | sump tank hjt | AISI 304 | 59.5098 lb | 205.903 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|--|
| Restraint-1 <sump tank hjt> | on 2 Face(s) fixed. |
| Description: | Tank bottom restrained where it contacts supports. |

| Load | | |
|---|--|--------------------|
| Pressure-1 <sump tank hjt> | on 2 Face(s) with Pressure 15 psi along direction normal to selected face | Sequential Loading |
| Description: | 15 psi internal pressure on bottom and wall. | |

4. Study Property

| Mesh Information | |
|-----------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.59061 in |
| Tolerance: | 0.029531 in |
| Quality: | High |
| Number of elements: | 17641 |
| Number of nodes: | 35493 |

| Solver Information | |
|--------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results


| Name | Type | Min | Location | Max | Location |
|------|------|-----|----------|-----|----------|
|------|------|-----|----------|-----|----------|

| | | | | | |
|-------|-----------------------|---------|----------|---------|----------|
| Plot1 | VON: von Mises stress | 13.6131 | (7.50297 | 4904.86 | (8.96416 |
| | | psi | in, | psi | in, |
| | | Node: | 0 in, | Node: | 0.546875 |
| | | 25974 | -3.2 in) | 5196 | in, |
| | | | | | 3.9911 |
| | | | | | in) |

sump tank hjt-Pressure1atm-Stress-Plot1

JPEG

Model name: sump tank hjt
 Study name: Pressure1atm
 Plot type: Static nodal stress Plot1
 Deformation scale: 379.796




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|------------------------|-----------------------------------|---------------------------------|----------------------------------|
| Plot1 | URES: Resultant displacement | 0 in Node: 24918 | (9.18681 in, 0 in, 3.95 in) | 0.00657775 in Node: 21565 | (0 in, 9.21094 in, -10 in) |

sump tank hjt-Pressure1atm-Displacement-Plot1

JPEG


Model name: sump tank hjt
Study name: Pressure1atm
Plot type: Static displacement Plot1
Deformation scale: 379.796



7. Design Check Results

sump tank hjt-Pressure1atm-Design Check-Plot1

JPEG



8. Conclusion

Area of highest stress near tank bottom close to support. Minimum safety factor > 6 , so tank is considered structurally sound for this loading condition.

9. Appendix

Material name: AISI 304

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 2.7557e+007 | psi | Constant |
| Poisson's ratio | 0.29 | NA | Constant |
| Shear modulus | 1.0878e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in ³ | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 1e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.000214 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Appendix D. Secondary Containment Documents


Mercury Removal From Gas Streams

Mercury Issues

Because of the extreme toxicity of mercury vapor, removal of mercury from air and process gas stream is critical for both safety and environmental compliance. The threshold limit value (TLV) for mercury exposure is 0.05 mg/m³. In addition, the presence of trace mercury in process gas streams (e.g. natural gas, hydrogen) can lead to significant process problems, such as corrosion and catalyst poisoning. Barnebey Sutcliffe provides three different products for vapor phase mercury control for different applications: activated carbon types CB, CBII, and CY. These products can reduce mercury to part per trillion levels and can achieve capacities as high as 20% by weight.

Development of CB Carbon


Virgin activated carbon has a relatively low capacity for mercury vapors. In 1960, Barnebey Sutcliffe developed the first generation of impregnated carbon to remove Hg. This product used potassium iodide (KI) and iodine (I₃) to react with mercury according to the following reaction:



Barnebey Sutcliffe today offers an improved version of this product under the trade name Type CB. It is used for specialty applications, such as H₂ purification because it is resistant to side reactions (H₂S formation).

Type CBII Carbon

Sulfur has long been known to be effective in removing mercury vapor via the following reaction:



Barnebey Sutcliffe has developed a proprietary process for impregnation of carbon with sulfur and carbon base materials that provided optimum pore structure for mercury capture. Using this technology Barnebey Sutcliffe markets a sulfur-impregnated product under the trade name CBII. CBII can achieve an adsorption capacity of 20% w/w under ideal conditions. It is widely used for mercury removal from air streams and from natural gas streams.

Type CY Carbon

CY is a specialty impregnated product specifically designed for use in mercury vapor respirators. It meets the stringent requirements of NIOSH for mercury protective equipment.

Design Considerations

Because mercury is so toxic, it is critical to properly design mercury adsorption systems. Efficiency of mercury removal is affected by temperature, pressure, relative humidity,

concentration of mercury, species of mercury (e.g. ionic, elemental), etc. Because mercury is chemisorbed on carbon, the residence time requirements are different than those for standard adsorption application. Please contact the Barnebey Sutcliffe technical department for assistance in designing a system for your particular application.

Test Data

Performance tests were conducted to compare CBII to other commercially available products. Miller-Nelson Research, Monterey, California performed the testing by passing 40 l/min. of zero air through a mercury diffusion vial to generate a 2 ppm mercury stream. The mercury stream then passed through a 2.5" x 7.5" adsorption column, and the inlet and outlet concentration were measured using a Jerome Meter. Three types of carbon were tested: CBII 4 x 10 and 2 commercially available carbons impregnated with >15% sulfur (Sample A and Sample B). The removal efficiency vs. bed volume feed date was collected at different time intervals and the results are shown below. The test was terminated after 10,000 bed volumes of air has passed through the column.


| Carbon | Initial Mercury Effluent | Time Until Test Completion |
|---------------|---------------------------------|-----------------------------------|
| CBII | Non-detect | 24 hours |
| Sample A | Non-detect | 24 hours |
| Sample B | Non-detect | 2 hours |

Operating Temperature


The maximum recommended operating temperature for CBII is 70 °C. Above this temperature, the performance for mercury removal declines appreciably. CBII has been used at temperatures up to 100 °C. Operation above this temperature may result in loss of sulfur impregnant. CBII has a high ignition temperature. Measurements of ignition temperature using ASTM Method D-346D range from 450 °C to over 500 °C.

Performance Data


FORMALDEHYDE REMOVAL DATA B&S ACTIVATED CARBON



AMMONIA SERVICE LIFE TEST B&S CARBON TYPE CY



Hg REMOVAL WITH B&S CARBON TYPE CB-II



CARBON SELECTION TABLE

| | 209CKINA | CY | CA | FormAsorb | ST | ETO | 487 | 727 | 717 | 787 | CBI | CBII |
|------------------|----------|----|----|-----------|----|-----|-----|-----|-----|-----|-----|------|
| CL2 | ● | | | | ● | | | | | | | |
| SO2 | ● | | | | ● | | | | | | | |
| NH3 | | ● | ● | | | ● | | | | | | |
| Monomethyl Amine | | ● | ● | | | | | | | | | |
| Formaldehyde | | | | ● | | | | | | | | |
| H2S | ● | | | | ● | | | | | | | |
| CLO2 | ● | | | | ● | | | | | | | |
| Methyl Iodine | | | | | ● | | ● | ● | ● | | | |
| HCL | ● | | | | ● | | | | | | | |
| HF | ● | | | | ● | | | | | | | |
| HBr | ● | | | | ● | | | | | | | |
| Ethylene Oxide | | | | | ● | ● | | | | | | |
| H2SO4 | ● | | | | ● | | | | | | | |
| Hg | ● | | | | | | | | | | ● | ● |

Note: CA replaced by AmmonAsorb II

Your Single Source Supplier

Barnebey & Sutcliffe provides quality activated carbon products and equipment along with highly skilled technical support and customer service. You can count on the most cost-effective materials available, custom designed to meet your specific applications. Make Barnebey & Sutcliffe your single source for all your specialty carbon requirements.

Tailor-Made Specialty Carbons

With more than 100 established impregnated carbons currently available, Barnebey & Sutcliffe has the expertise and applications experience to design a special carbon adsorbent for your needs.

"This technical information remains the exclusive property of Barnebey & Sutcliffe Corporation. All authorized copies are loaned in good faith and subject to return upon request. Any further reproduction without the consent of Barnebey & Sutcliffe Corporation is thereby prohibited."

* All tests conducted by Miller-Nelson Research, Inc.

For more information on a specific specialty carbon to meet your application requirements, call or write:

Barnebey & Sutcliffe Corporation
 P.O. Box 2526
 Columbus, Ohio 43216
 Telephone: 614-258-9501
 Fax number: 614-258-3464



Stress Analysis of Secondary Containment Box Supports

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: May 19, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis is performed of the rectangular tubes that support the secondary containment box. Loading condition simulated put one-half Hg system weight (2000 lbs) to tube top surface. Loading direction simulated slope of TT2 tunnel.

Vertical (normal) load on surface: $2000 * \cos(4.2) = 1995 \text{ lb}$

Horizontal load on surface: $2000 * \sin(4.2) = 150 \text{ lb}$

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|-------------------------|--|------------|-------------------------|
| 1 | rect tubing support hjt | AISI 316 Annealed Stainless Steel Bar (SS) | 47.6618 lb | 164.909 in ³ |
| 2 | rect tubing support hjt | AISI 316 Annealed Stainless Steel Bar (SS) | 47.6618 lb | 164.909 in ³ |
| 3 | rect tubing support hjt | AISI 316 Annealed Stainless Steel Bar (SS) | 47.6618 lb | 164.909 in ³ |
| 4 | rect tubing support hjt | AISI 316 Annealed Stainless Steel Bar (SS) | 47.6618 lb | 164.909 in ³ |

3. Load & Restraint Information

| Restraint | |
|---------------------------------------|----------------------------|
| Restraint-1 <rect tubing support hjt> | on 1 Face(s) fixed. |
| Description: | Bottom surface restrained. |

| Load | | |
|--|---|--------------------|
| Force-1 <rect tubing support hjt> | on 1 Face(s) apply normal force 1995 lb using uniform distribution | Sequential Loading |
| Description: | 2000 lbs on top surface with 4.2deg inclination. | |
| Force-2 <rect tubing support hjt> | on 1 Face(s) apply force -150 lb normal to reference plane with respect to selected reference Edge< 1 > using uniform distribution | Sequential Loading |
| Description: | | |

4. Study Property

| Mesh Information | |
|-------------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.54849 in |
| Tolerance: | 0.027424 in |
| Quality: | High |
| Number of elements: | 14228 |
| Number of nodes: | 28696 |


| Solver Information | |
|---------------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|-------------------------------------|---|----------------------------------|--|
| Plot1 | VON: von Mises stress | 0.00873863 psi Node: 18480 | (- 0.269231 in, -1.5 in, 11.1336 in) | 3792.81 psi Node: 19738 | (3.5 in, -1.375 in, - 15.8854 in) |

rect tubing support hjt-HgSysWeight-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|------------|-----------|
| Plot1 | URES: Resultant displacement | 0 in | (3.5 in, | 0.00291197 | (- |
| | | Node: | -1.5 in, | in | 5.63193e- |

| | | | | | |
|--|--|-------|--------------|------------|------------------------------|
| | | 16457 | 15.75 in) | Node: 4390 | 009 in, 1.5 in, 19 in) |
|--|--|-------|--------------|------------|------------------------------|

rect tubing support hjt-HgSysWeight-Displacement-Plot1

JPEG

Model name: rect tubing support hjt
 Study name: HgSys/Weight
 Plot type: Static displacement Plot1
 Deformation scale: 500




7. Design Check Results

rect tubing support hjt-HgSysWeight-Design Check-Plot1

JPEG

Model name: rect tubing support hjt
Study name: HgSysWeight
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 5.3



8. Conclusion

Analysis indicates minimum safety factor > 5. Tube considered structurally sound for simulated loading condition.

9. Appendix

Material name: AISI 316 Annealed Stainless Steel Bar (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|--|-------------|--------------------|------------|
| Elastic modulus | 2.7992e+007 | psi | Constant |
| Poisson's ratio | 0.3 | NA | Constant |
| Mass density | 0.28902 | lb/in ³ | Constant |
| Tensile strength | 79771 | psi | Constant |
| Yield strength | 20000 | psi | Constant |
| Thermal expansion coefficient | 8.8889e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 0.00021801 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Downstream Double Beam Window

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: Feb 16, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the downstream secondary beam window is performed. Loading condition is 1atm internal pressure, which simulates window monitoring conditions.

Analysis does not consider any beam-induced stresses.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|-------------------|------------------------------|-------------|-------------------------|
| 1 | double window hjt | User Defined | 0.491469 lb | 3.07168 in ³ |
| 2 | double window hjt | User Defined | 0.491469 lb | 3.07168 in ³ |
| 3 | double window hjt | User Defined | 0.491469 lb | 3.07168 in ³ |
| 4 | double window hjt | User Defined | 0.491469 lb | 3.07168 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|------------------------------|
| Restraint-1 <double window hjt> | on 1 Face(s) fixed. |
| Description: | Flange fixed. |
| Restraint-2 <double window hjt> | on 4 Face(s) symmetry |
| Description: | |

| Load | | |
|-------------------------------------|---|--------------------|
| Pressure-1 <double window | on 3 Face(s) with Pressure 15 psi along direction normal to selected face | Sequential Loading |

| | | |
|---------------------|----------------------------------|--|
| hjt> | | |
| Description: | 15 psi on all internal surfaces. | |

4. Study Property

| Mesh Information | |
|-------------------------|--------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.11088 in |
| Tolerance: | 0.0055439 in |
| Quality: | High |
| Number of elements: | 19276 |
| Number of nodes: | 36992 |


| Solver Information | |
|---------------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|---------------------------------|--|----------------------------------|---|
| Plot1 | VON: von Mises stress | 3.41338 psi Node: 3224 | (- 2.00785 in, - 1.19598 in, 1 in) | 18025.4 psi Node: 29934 | (- 0.994874 in, -1.77189 in, -0.952 in) |

double window hjt-Pressure1atm-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|--------------------|---------------|-----------------------|----------------|---------------------|
| Plot1 | URES: Resultant | 0 in Node: | (4.13318e- 016 in, | 0.032628 in | (0.000173533 in, |

| | | | | |
|--------------|----|--------------------|----------------|---------------------|
| displacement | 35 | -2.25 in, 1 in) | Node: 36345 | 0 in, -0.976 in) |
|--------------|----|--------------------|----------------|---------------------|

double window hjt-Pressure1atm-Displacement-Plot1

JPEG

Model name: double window hjt
Study name: Pressure1atm
Plot type: Static displacement Plot1
Deformation scale: 16.8567




7. Design Check Results

double window hjt-Pressure1atm-Design Check-Plot1

JPEG

Model name: double window hjt
Study name: Pressure1atm
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 7.1



8. Conclusion

Analysis indicates minimum safety factor > 7 for the window membranes, not considering any beam interactions. For the condition simulated, the structure is considered adequate.

9. Appendix

Material name: User Defined

Description:

Material Source: Input

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.52e+007 | psi | Constant |
| Poisson's ratio | 0.31 | NA | Constant |
| Shear modulus | 5.95e+006 | psi | Constant |
| Mass density | 0.16 | lb/in ³ | Constant |
| Tensile strength | 1.2e+005 | psi | Constant |
| Yield strength | 1.28e+005 | psi | Constant |
| Thermal expansion coefficient | 5e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 8.9611e-005 | BTU/(in.s.F) | Constant |
| Specific heat | 0.14 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Target Module Support Cradle

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: Feb 8, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the target module support cradle is performed. Target module weight was estimated at 200 lbs for this analysis. An important simplification made was that the turnbuckles which provide vertical support were not included; thus the cradle was analyzed as self-supporting.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|--------------------|------------------------------|------------|-------------------------|
| 1 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |
| 2 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |
| 3 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |
| 4 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |
| 5 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |
| 6 | support cradle hjt | 6061-T6 (SS) | 13.4186 lb | 137.565 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|---|
| Restraint-1 <support cradle hjt> | on 2 Face(s) fixed. |
| Description: | Pads were restrained horizontally and vertically. |

| Load | | |
|-------------------------|--|------------|
| Force-1 <support | on 1 Face(s) apply force 200 lb normal | Sequential |

| | | |
|-----------------------|---|---------|
| cradle hjt> | to reference plane with respect to selected reference Edge< 1 > using uniform distribution | Loading |
| Description: | Target module weight simulated as 200 lb vertical load. | |

4. Study Property

| Mesh Information | |
|-------------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.51633 in |
| Tolerance: | 0.025816 in |
| Quality: | High |
| Number of elements: | 15445 |
| Number of nodes: | 31017 |


| Solver Information | |
|---------------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------|-----------|---------|-----------|
| Plot1 | VON: von Mises stress | 0.268075 | (0.5 in, | 14115.6 | (0.719063 |
| | | psi | -1.75 in, | psi | in, |
| | | Node: | 10.725 | Node: | 1.21296 |
| | | 29395 | in) | 17171 | in, |
| | | | | | -12.9818 |
| | | | | | in) |

support cradle hjt-TargetWeight-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|----------|----------|
| Plot1 | URES: Resultant displacement | 0 in | (0 in, | 0.649145 | (40 in, |
| | | Node: | 2 in, | in | 17.9149 |

| | | | | | |
|--|--|-------|---------------|--------------|----------------------------|
| | | 28395 | 16.725 in) | Node: 742 | in, - 3.46455 in) |
|--|--|-------|---------------|--------------|----------------------------|

support cradle hjt-TargetWeight-Displacement-Plot1

JPEG

Model name: support cradle hjt
 Study name: TargetWeight
 Plot type: Static displacement Plot1
 Deformation scale: 6.73691




7. Design Check Results

support cradle hjt-TargetWeight-Design Check-Plot1

JPEG

Model name: support cradle hjt
Study name: TargetWeight
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 2.8



8. Conclusion

Analysis indicates minimum safety factor of 2.8 for this loading condition. Considering that the turnbuckles provide most of the vertical support, this analysis indicates the cradle structure is adequate for this loading condition.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Appendix E. Base Support Structure Documents



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION

Baseplate Lift Point Welds

SHEET 1 OF 1

DRAWING NO

203-HJT-0110 Weld W-1

CALCULATION BY V. Graves

DATE 12 Apr 2006

Lift point welds on the baseplate are checked. Symmetric loading assumed. Baseplate lifted with no other loads!

$$W := 1000\text{lb}$$

Baseplate weight

$$F := \frac{W}{4}$$

Load on each lift point

$$S_y := 40000\text{psi}$$

Tensile yield strength Al 6061-T6

$$S_{sy} := 0.58S_y$$

Distortion energy criteria for shear strength

$$h := 0.375\text{in}$$

Weld leg length

$$t := 0.707 \cdot h$$

Weld throat

$$L := 1.5\text{in}$$

Weld length

$$A := 2t \cdot L$$

Weld stress area. Neglect horizontal weld segments.

$$\text{shear} := \frac{F}{A}$$

$$\text{shear} = 314.317\text{ psi}$$

Shear stress

$$FS := \frac{S_{sy}}{\text{shear}}$$

$$FS = 73.811$$

Safety Factor



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION

Hydraulic Jack Bracket Welds

SHEET 1 OF 1

DRAWING NO

203-HJT-0131 Weld W-1

CALCULATION BY V. Graves

DATE 12 Apr 2006

Four jacking brackets are attached to the baseplate. Worst case loading is for the two under the magnet, with assumed loads of magnet and half the baseplate weight.

$$W_{\text{mag}} := 12000 \text{ lbf} \quad \text{Magnet weight}$$

$$W_{\text{base}} := 1000 \text{ lbf} \quad \text{Baseplate weight}$$

$$F := \frac{W_{\text{mag}} + 0.5W_{\text{base}}}{2} \quad \text{Load on one bracket}$$

$$F = 6.25 \times 10^3 \text{ lbf}$$

$$S_y := 40000 \text{ psi} \quad \text{Tensile yield strength Al 6061-T6}$$

$$S_{sy} := 0.58S_y \quad \text{Distortion energy criteria for shear strength}$$

$$h := 0.25 \text{ in} \quad \text{Weld leg length}$$

$$t := 0.707 \cdot h \quad \text{Weld throat}$$

$$L := 11.25 \text{ in} \quad \text{Weld length}$$

$$A := 2t \cdot L \quad \text{Weld stress area}$$

$$\text{Out-of-plane eccentric loading} \quad d := 2.25 \text{ in} \quad \text{Offset}$$

$$M := F \cdot d \quad \text{Bending moment}$$

$$I_v := \frac{L^3 t}{12} \quad I_x := 2 \cdot I_v \quad \text{Weld segment moment of inertia}$$

$$\text{normal} := \frac{M \cdot L}{2 \cdot I_x} \quad \text{normal} = 1.886 \times 10^3 \text{ psi} \quad \text{Normal stress}$$

$$\text{shear} := \frac{F}{A} \quad \text{shear} = 1.572 \times 10^3 \text{ psi} \quad \text{Shear stress}$$

$$\text{total} := \sqrt{\text{normal}^2 + \text{shear}^2} \quad \text{total} = 2.455 \times 10^3 \text{ psi} \quad \text{total stress assumed to act in shear plane}$$

$$\text{FS} := \frac{S_{sy}}{\text{total}} \quad \text{FS} = 9.451 \quad \text{Safety Factor}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION

Hydraulic Jack Bracket Welds

SHEET 1 OF 1

DRAWING NO

203-HJT-0131 Weld W-2

CALCULATION BY V. Graves

DATE 12 Apr 2006

Four jacking brackets are attached to the baseplate. Worst case loading is for the two under the magnet, with assumed loads of magnet and half the baseplate weight.

$$W_{\text{mag}} := 12000 \text{ lbf} \quad \text{Magnet weight}$$

$$W_{\text{base}} := 1000 \text{ lbf} \quad \text{Baseplate weight}$$

$$F := \frac{W_{\text{mag}} + 0.5W_{\text{base}}}{2} \quad \text{Load on one bracket}$$

$$F = 6.25 \times 10^3 \text{ lbf}$$

$$S_y := 40000 \text{ psi} \quad \text{Tensile yield strength Al 6061-T6}$$

$$S_{sy} := 0.58S_y \quad \text{Distortion energy criteria for shear strength}$$

$$h := 0.25 \text{ in} \quad \text{Weld leg length} \quad \text{Only consider fillet welds}$$

$$t := 0.707 \cdot h \quad \text{Weld throat}$$

$$L := 5 \text{ in} \quad \text{Weld length}$$

$$A := 2t \cdot L \quad \text{Weld stress area}$$

$$\text{shear} := \frac{F}{A} \quad \text{shear} = 3.536 \times 10^3 \text{ psi} \quad \text{Shear stress}$$

$$\text{FS} := \frac{S_{sy}}{\text{shear}} \quad \text{FS} = 6.561 \quad \text{Safety Factor}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION

Hydraulic Jack Bracket Welds

SHEET 1 OF 1

DRAWING NO

203-HJT-0131 Weld W-1

CALCULATION BY V. Graves

DATE 12 Apr 2006

Four jacking brackets are attached to the baseplate. Worst case loading is for the two under the magnet, with assumed loads of magnet and half the baseplate weight.

$$W_{\text{mag}} := 12000 \text{ lbf} \quad \text{Magnet weight}$$

$$W_{\text{base}} := 1000 \text{ lbf} \quad \text{Baseplate weight}$$

$$F := \frac{W_{\text{mag}} + 0.5W_{\text{base}}}{2} \quad \text{Load on one bracket}$$

$$F = 6.25 \times 10^3 \text{ lbf}$$

$$S_y := 40000 \text{ psi} \quad \text{Tensile yield strength Al 6061-T6}$$

$$S_{sy} := 0.58S_y \quad \text{Distortion energy criteria for shear strength}$$

$$h := 0.25 \text{ in} \quad \text{Fillet weld leg length} \quad h_{\text{vweld}} := .5 \text{ in} \quad \text{V weld leg length}$$

$$t := 0.707 \cdot h \quad \text{Fillet weld throat} \quad t_{\text{vweld}} := 0.707h_{\text{vweld}} \quad \text{V weld throat}$$

$$L := 11.25 \text{ in} \quad \text{Weld length}$$

$$A := 2t \cdot L + 2 \cdot t_{\text{vweld}} \cdot L \quad \text{Weld stress area}$$

$$\text{Out-of-plane eccentric loading} \quad d := 2.25 \text{ in} \quad \text{Offset}$$

$$M := F \cdot d \quad \text{Bending moment}$$

$$I_v := \frac{L^3 t}{12} \quad I_x := 2 \cdot I_v \quad \text{Weld segment moment of inertia}$$

$$\text{normal} := \frac{M \cdot L}{2 \cdot I_x} \quad \text{normal} = 1.886 \times 10^3 \text{ psi} \quad \text{Normal stress}$$

$$\text{shear} := \frac{F}{A} \quad \text{shear} = 523.862 \text{ psi} \quad \text{Shear stress}$$

$$\text{total} := \sqrt{\text{normal}^2 + \text{shear}^2} \quad \text{total} = 1.957 \times 10^3 \text{ psi} \quad \text{total stress assumed to act in shear plane}$$

$$\text{FS} := \frac{S_{sy}}{\text{total}} \quad \text{FS} = 11.853 \quad \text{Safety Factor}$$



MERIT Calculation Sheet

Oak Ridge National Laboratory

CALCULATION Hg Cart Bracket Loading

SHEET 1 OF 1

DRAWING NO 203-HJT-0120

CALCULATION BY V.B. Graves

DATE 3 Feb 2006

The loading condition on the Hg delivery system jacking bracket is calculated. This bracket is located on the common baseplate and the target transporter. Worst case loading occurs on the target transporter when the Hg system is being lowered down the sloped TT2 tunnel.

W := 4000lbf Conservative assumption of system with Hg

θ := 4.23deg tt2 floor slope

h := 5in height of horizontal jack bolt hole above base

d := 2in distance from vertical shcs hole to edge of bracket. used to determine load on tie-down bolt.

F := W · sin(θ) F = 295.042 lbf force on jack bolt

M := F · h M = 1.475 × 10³ lbf · in moment on bracket

T := $\frac{M}{d}$ T = 737.604 lbf tension force on vertical shcs

SHCS material is SS 18-8 with minimum yield of 100,000 psi. Diameter is 0.75inch, so stress on bolt is

$$\text{stress} := \frac{T \cdot 4}{\pi \cdot (0.75\text{in})^2} \quad \text{stress} = 1.67 \times 10^3 \text{ psi}$$

$$\text{safety} := \frac{100000\text{psi}}{\text{stress}} \quad \text{safety} = 59.895$$

Stress Analysis of Cart Restraint Bracket

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: May 19, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the cart jacking bracket is performed. Loading condition simulates Hg delivery system resting against horizontal jack bolt while entire assembly is on the sloped floor of the TT2 tunnel (4.23 deg slope).

Horizontal load on hole threads is $4000 * \sin(4.23) = 300$ lb.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|------------------------|------------------------------|------------|-------------------------|
| 1 | cart jacking plate hjt | 6061-T6 (SS) | 2.45111 lb | 25.1284 in ³ |
| 2 | cart jacking plate hjt | 6061-T6 (SS) | 2.45111 lb | 25.1284 in ³ |
| 3 | cart jacking plate hjt | 6061-T6 (SS) | 2.45111 lb | 25.1284 in ³ |

3. Load & Restraint Information

| Restraint | |
|---|-----------------------------------|
| Restraint-1 <cart jacking plate hjt> | on 1 Face(s) fixed. |
| Description: | Vertical hole threads restrained. |

| Load | | |
|---|--|--------------------|
| Force-1 <cart jacking plate hjt> | on 1 Face(s) apply force 300 lb normal to reference plane with respect to selected reference Face< 1 > using uniform distribution | Sequential Loading |
| Description: | Horizontal hole thread loaded by jack bolt. | |

4. Study Property

| Mesh Information | |
|-------------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.29298 in |
| Tolerance: | 0.014649 in |
| Quality: | High |
| Number of elements: | 4993 |
| Number of nodes: | 9458 |


| Solver Information | |
|---------------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|------------|--------------------|-------------|---------------------------------------|
| Plot1 | VON: von Mises stress | 13.214 psi | (2 in, 6 in, 0 in) | 10880.8 psi | (2.41704e-008 in, 0.5 in, 1.85937 in) |
| | | Node: 2155 | | Node: 8007 | |

cart jacking plate hjt-TunnelLoading-Stress-Plot1

JPEG




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-----------------------|---|----------------------------------|--------------------------|
| Plot1 | URES: Resultant displacement | 0 in Node: 1657 | (0.338291 in, 0.5 in, 2.05469 in) | 0.0120834 in Node: 2148 | (0 in, 6 in, 0 in) |

cart jacking plate hjt-TunnelLoading-Displacement-Plot1


JPEG



7. Design Check Results

cart jacking plate hjt-TunnelLoading-Design Check-Plot1

JPEG



8. Conclusion

Maximum stress located near vertical hole, with a corresponding safety factor > 3 . Stresses in this region are localized and would relieve as necessary. Bracket considered structurally sound for the simulated loading condition.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Magnet Support Beam

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: May 11, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the baseplate support beam is performed. Loading condition simulates in-beam conditions with the beam supporting a percentage of the weights of the magnet (6T), Hg system (2T), and baseplate (800 lbs). Manual calculations show the resultant load on the beam to be 11600 lbs. Loading was evenly distributed on the two circular recesses and applied vertically.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|------------------------|------------------------------|------------|-------------------------|
| 1 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 2 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 3 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 4 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 5 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 6 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 7 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 8 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 9 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 10 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 11 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 12 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |
| 13 | magnet end support hjt | 6061-T6 (SS) | 28.4115 lb | 291.269 in ³ |

3. Load & Restraint Information

| Restraint | |
|---|---------------------|
| Restraint-1 <magnet end support hjt> | on 2 Face(s) fixed. |

| | |
|---------------------|---------------------|
| Description: | Bottom faces fixed. |
|---------------------|---------------------|

| Load | | |
|---|--|--------------------|
| Force-1 <magnet end support hjt> | on 2 Face(s) apply normal force 5800 lb using uniform distribution | Sequential Loading |
| Description: | Vertical loading on both recesses. | |

4. Study Property

| Mesh Information | |
|-------------------------|------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.66299 in |
| Tolerance: | 0.03315 in |
| Quality: | High |
| Number of elements: | 14905 |
| Number of nodes: | 29272 |


| Solver Information | |
|---------------------------|---|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------------|---|----------------------------------|--|
| Plot1 | VON: von Mises stress | 0.314444 psi Node: 9949 | (- 0.0644952 in, 1.16065 in, -1.52176 in) | 3083.53 psi Node: 28859 | (1.75 in, 2.23333 in, - 22.5625 in) |

magnet end support hjt-magnet load-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|------------|-----------|
| Plot1 | URES: Resultant displacement | 0 in | (5 in, | 0.00143937 | (0.333333 |
| | | Node: | -3.5 in, | in | in, |

| | | | | | |
|--|--|-------|--------------|----------------|-----------------------------|
| | | 22000 | 24.75 in) | Node: 26759 | 3.125 in, -22.727 in) |
|--|--|-------|--------------|----------------|-----------------------------|

magnet end support hjt-magnet load-Displacement-Plot1

JPEG

Model name: magnet end support hjt
 Study name: magnet load
 Plot type: Static displacement Plot1
 Deformation scale: 3458.23




7. Design Check Results

magnet end support hjt-magnet load-Design Check-Plot1

JPEG

Model name: magnet end support hjt
Study name: magnet load
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 13



8. Conclusion

Based on maximum calculated stresses, the safety factor is much greater than 3 when compared to material yield strength. The design is considered adequate for the loading condition simulated.

9. Appendix

| | |
|-------------------------------|--------------------------|
| Material name: | 6061-T6 (SS) |
| Description: | |
| Material Source: | Library files |
| Material Library Name: | cosmos materials |
| Material Model Type: | Linear Elastic Isotropic |

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Common Baseplate - 4 Levelers

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: March 14, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the common base assembly is performed. The loading condition simulates that encountered when the loaded baseplate (magnet & Hg system) is supported by four leveling jacks. Since the jacking brackets are mechanically attached to the baseplate, the attachment holes were restrained in this analysis. The brackets will be analyzed separately.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|------------------------|------------------------------|---------------|----------------------------|
| 1 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 2 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 3 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 4 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 5 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 6 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 7 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 8 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 9 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 10 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 11 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 12 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |

| | | | | |
|----|------------------------|------------------------------|---------------|----------------------------|
| 13 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 14 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 15 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 16 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 17 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 18 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 19 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 20 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 21 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 22 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 23 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 24 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 25 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 26 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 27 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 28 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 29 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 30 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 31 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 32 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |

| | | | | |
|----|-------------------------------|--|---------------|----------------------------|
| 33 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 34 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 35 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 36 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 37 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 38 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 39 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 40 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 41 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 42 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 43 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 44 | flat rail hjt-1 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 45 | flat rail hjt-2 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 46 | magnet support plate hjt-1 | 6061-T6 (SS) | 205.676 lb | 2108.55 in ³ |
| 47 | slick sheet hjt-1 | Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS) | 2.32213 lb | 455.861 in ³ |

3. Load & Restraint Information

| |
|------------------|
| Restraint |
|------------------|

| | |
|--|--------------------------------------|
| Restraint-5 <base weldment hjt-1> | on 8 Face(s) fixed. |
| Description: | Bracket attachment holes restrained. |

| Load | | |
|---|--|--------------------|
| Force-1 <magnet support plate hjt-1> | on 4 Face(s) apply normal force 3000 lb using uniform distribution | Sequential Loading |
| Description: | Magnet weight (6T) distributed on support plate pads. | |
| Force-2 <flat rail hjt-2, flat rail hjt-1> | on 4 Face(s) apply normal force 1000 lb using uniform distribution | Sequential Loading |
| Description: | Hg system weight (2T) distributed on rails at wheel contact locations. | |

4. Study Property

| Mesh Information | |
|-------------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 1.9207 in |
| Tolerance: | 0.096036 in |
| Quality: | High |
| Number of elements: | 35123 |
| Number of nodes: | 63665 |

| Solver Information | |
|---------------------------|------|
| Quality: | High |


| | |
|-----------------|---|
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------------|---|----------------------------------|---|
| Plot1 | VON: von Mises stress | 1.33608 psi Node: 63616 | (25.9546 in, 2.875 in, -4.99199 in) | 23640.5 psi Node: 39565 | (43.1172 in, -1.10502 in, -19.84 in) |

common base assy hjt-jacks-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|-----------|----------|
| Plot1 | URES: Resultant displacement | 0 in | (46.8828 | 0.0736117 | (3 in, |
| | | Node: | in, | in | 3.875 |

| | | | | | |
|--|--|-----|----------------------------------|----------------|---------------|
| | | 107 | 0.644984 in, -19.68 in) | Node: 48521 | in, 19 in) |
|--|--|-----|----------------------------------|----------------|---------------|

common base assy hjt-jacks-Displacement-Plot1

JPEG

Model name: common base assy hjt
 Study name: jacks
 Plot type: Static displacement Plot1
 Deformation scale: 171.337




7. Design Check Results

common base assy hjt-jacks-Design Check-Plot1

JPEG


Model name: common base assy hjt
Study name: jacks
Plot type: Design Check Plot1
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 24



common base assy hjt-jacks-Design Check-Plot2

JPEG


Model name: common.base assy hjt
Study name: jacks
Plot type: Design Check Plot2
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 2.1



common base assy hjt-jacks-Design Check-Plot3

JPEG


Model name: common base assy hjt
Study name: jacks
Plot type: Design Check Plot3
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 1.7



common base assy hjt-jacks-Design Check-Plot4


JPEG

Model name: common base assy hjt
Study name: jacks
Plot type: Design Check Plot4
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 11



common base assy hjt-jacks-Design Check-Plot5

JPEG



8. Conclusion

There are some local areas of high stress near the bolt holes in which the calculated safety factor is less than 3. However, these areas are very localized and are not indicative of a high general stress level.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Material name: Wrought Stainless Steel

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-----------------|-------------|-------|------------|
| Elastic modulus | 2.9008e+007 | psi | Constant |

| | | | |
|-------------------------------|-------------|--------------|----------|
| Poisson's ratio | 0.26 | NA | Constant |
| Shear modulus | 1.1458e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in^3 | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 6.1111e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 0.00025412 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Material name: Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|--|-------------|---------|------------|
| Elastic modulus | 4.2061e+005 | psi | Constant |
| Poisson's ratio | 0.3 | NA | Constant |
| Mass density | 0.0050939 | lb/in^3 | Constant |
| Tensile strength | 5903 | psi | Constant |
| Yield strength | 9137.4 | psi | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Hydraulic Jack Weldment

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: May 5, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the hydraulic jack weldment is performed. The loading condition simulated mimics the worst case scenario of a loaded baseplate (weight of magnet, Hg system, and baseplate). The load applied was manually calculated based on the distances between the load points and the bracket locations.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|-----------------------|--------------------------------|------------|-------------------------|
| 1 | hyd jack weldment hjt | [SW]6061 Alloy | 7.34375 lb | 75.2868 in ³ |
| 2 | hyd jack weldment hjt | [SW]6061 Alloy | 7.34375 lb | 75.2868 in ³ |
| 3 | hyd jack weldment hjt | [SW]6061 Alloy | 7.34375 lb | 75.2868 in ³ |
| 4 | hyd jack weldment hjt | [SW]6061 Alloy | 7.34375 lb | 75.2868 in ³ |

3. Load & Restraint Information

| Restraint | |
|--|-----------------------------|
| Restraint-1 <hyd jack weldment hjt> | on 1 Face(s) fixed. |
| Description: | Top of weldment held fixed. |

| Load | | |
|--|--|--------------------|
| Force-1 <hyd jack weldment hjt> | on 2 Face(s) apply force -3000 lb normal to reference plane with respect to selected reference Edge< 1 > using uniform distribution | Sequential Loading |
| Description: | Total load (6000lbs) evenly distributed | |

| | | |
|--|------------------------|--|
| | on the two bolt holes. | |
|--|------------------------|--|

4. Study Property

| Mesh Information | |
|-----------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 0.42235 in |
| Tolerance: | 0.021117 in |
| Quality: | High |
| Number of elements: | 5513 |
| Number of nodes: | 11121 |

| Solver Information | |
|--------------------|---|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |


5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|-----------------------------------|-------------------------------------|---------------------------------|---|
| Plot1 | VON: von Mises stress | 0.0528316 psi Node: 6003 | (-3 in, -0.125 in, 5.5 in) | 5639.15 psi Node: 2377 | (2.05831 in, -10.0128 in, 0 in) |

hyd jack weldment hjt-loaded-Stress-Plot1

JPEG

Model name: hyd jack weldment hjt
 Study name: loaded
 Plot type: Static nodal stress Plot1
 Deformation scale: 226.331




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|------------------|----------------------------------|--------------------------------|----------------------------------|
| Plot1 | URES: Resultant displacement | 0 in Node: 19 | (-2.5 in, -0.5 in, 0.5 in) | 0.00541518 in Node: 2145 | (2 in, -11.25 in, 0 in) |

hyd jack weldment hjt-loaded-Displacement-Plot1


JPEG



7. Design Check Results

hyd jack weldment hjt-loaded-Design Check-Plot1

JPEG



8. Conclusion

The analysis indicates localized high stresses near the bolt holes, but no stresses are above yield strength of the material. Any local deformation will relieve the stresses, so the structure is considered adequate for the simulated loading condition.

9. Appendix

Material name: [SW]6061 Alloy

Description:

Material Source: Used SolidWorks material

Material Library Name:

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 17997 | psi | Constant |
| Yield strength | 7998.6 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022737 | BTU/(in.s.F) | Constant |
| Specific heat | 0.31056 | Btu/(lb.F) | Constant |

Stress Analysis of Common Baseplate - 4 Levelers

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: March 14, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the common base assembly is performed. The loading condition simulates that encountered when the loaded baseplate (magnet & Hg system) is supported by four leveling jacks.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|------------------------|------------------------------|---------------|----------------------------|
| 1 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 2 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 3 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 4 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 5 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 6 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 7 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 8 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 9 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 10 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 11 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 12 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 13 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |

| | | | | |
|----|------------------------|------------------------------|---------------|----------------------------|
| 14 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 15 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 16 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 17 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 18 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 19 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 20 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 21 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 22 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 23 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 24 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 25 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 26 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 27 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 28 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 29 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 30 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 31 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 32 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 33 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |

| | | | | |
|----|-------------------------------|--|---------------|----------------------------|
| 34 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 35 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 36 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 37 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 38 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 39 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 40 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 41 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 42 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 43 | base weldment hjt-1 | 6061-T6 (SS) | 447.976 lb | 4592.57 in ³ |
| 44 | flat rail hjt-1 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 45 | flat rail hjt-2 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 46 | magnet support plate hjt-1 | 6061-T6 (SS) | 205.676 lb | 2108.55 in ³ |
| 47 | slick sheet hjt-1 | Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS) | 2.32213 lb | 455.861 in ³ |

3. Load & Restraint Information

| Restraint | |
|-----------------------------------|---------------------|
| Restraint-3 <base weldment hjt-1> | on 4 Face(s) fixed. |

| | |
|---------------------|--|
| Description: | Threaded holes for leveling jacks are fixed. |
|---------------------|--|

| Load | | |
|---|--|--------------------|
| Force-1 <magnet support plate hjt-1> | on 4 Face(s) apply normal force 3000 lb using uniform distribution | Sequential Loading |
| Description: | Magnet weight (6T) distributed on support plate pads. | |
| Force-2 <flat rail hjt-2, flat rail hjt-1> | on 4 Face(s) apply normal force 1000 lb using uniform distribution | Sequential Loading |
| Description: | Hg system weight (2T) distributed on rails at wheel contact locations. | |

4. Study Property

| Mesh Information | |
|-------------------------|------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 1.6804 in |
| Tolerance: | 0.08402 in |
| Quality: | High |
| Number of elements: | 45106 |
| Number of nodes: | 81757 |

| Solver Information | |
|---------------------------|-------------------------|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |


| | |
|-----------------|---|
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------------|---|----------------------------------|--|
| Plot1 | VON: von Mises stress | 1.59852 psi Node: 58699 | (- 59.2137 in, 0.302294 in, -2.5138 in) | 17874.7 psi Node: 35675 | (36.3789 in, -1.25 in, 22.0312 in) |

common base assy hjt-levelers-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|-----------|----------|
| Plot1 | URES: Resultant displacement | 0 in | (36.3789 | 0.0434563 | (63 in, |
| | | Node: | in, | in | 2.625 |

| | | | | | |
|--|--|-------|----------------------------|---------------|-----------------|
| | | 35637 | -0.5 in, 22.0312 in) | Node: 2545 | in, 9.25 in) |
|--|--|-------|----------------------------|---------------|-----------------|

common base assy hjt-levelers-Displacement-Plot1

JPEG

Model name: common base assy hjt
Study name: levelers
Plot type: Static displacement Plot1
Deformation scale: 290.19




7. Design Check Results

common base assy hjt-levelers-Design Check-Plot12

JPEG


Model name: common base assy hjt
Study name: levelers
Plot type: Design Check Plot12
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 2.2



common base assy hjt-levelers-Design Check-Plot17

JPEG


Model name: common base assy hjt
Study name: levelers
Plot type: Design Check Plot17
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 6.3



common base assy hjt-levelers-Design Check-Plot18

JPEG


Model name: common base assy hjt
Study name: levelers
Plot type: Design Check Plot18
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 97



common base assy hjt-levelers-Design Check-Plot4


JPEG

Model name: common base assy hjt
Study name: levelers
Plot type: Design Check Plot4
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 20



common base assy hjt-levelers-Design Check-Plot5

JPEG



8. Conclusion

Analysis indicates minimum safety factor (2.2) near edge of leveling jack holes under magnet. These are localized stresses and are not indicative of a general stress level. Local deformation will relieve these stresses, so the baseplate design is considered structurally

adequate for the simulated loading condition.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Material name: Wrought Stainless Steel

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-------------------------------|-------------|--------------------|------------|
| Elastic modulus | 2.9008e+007 | psi | Constant |
| Poisson's ratio | 0.26 | NA | Constant |
| Shear modulus | 1.1458e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in ³ | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 6.1111e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 0.00025412 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Material name: Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|--|-------------|--------------------|------------|
| Elastic modulus | 4.2061e+005 | psi | Constant |
| Poisson's ratio | 0.3 | NA | Constant |
| Mass density | 0.0050939 | lb/in ³ | Constant |
| Tensile strength | 5903 | psi | Constant |
| Yield strength | 9137.4 | psi | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Common Baseplate - 3 Rollers

Author: Author: Van Graves

Company: Oak Ridge National Laboratory

Date: April 23, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the common base assembly is performed. The loading condition simulates one encountered when the loaded baseplate (with magnet & Hg system) is supported by three Hilman rollers. This situation will occur during system alignment with the beamline.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|------------------------|------------------------------|---------------|----------------------------|
| 1 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 2 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 3 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 4 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 5 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 6 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 7 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 8 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 9 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 10 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 11 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 12 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |

| | | | | |
|----|------------------------|------------------------------|---------------|----------------------------|
| 13 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 14 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 15 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 16 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 17 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 18 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 19 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 20 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 21 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 22 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 23 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 24 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 25 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 26 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 27 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 28 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 29 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 30 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 31 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 32 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |

| | | | | |
|----|-------------------------------|--|---------------|----------------------------|
| 33 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 34 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 35 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 36 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 37 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 38 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 39 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 40 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 41 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 42 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 43 | base weldment hjt-1 | 6061-T6 (SS) | 428.213 lb | 4389.96 in ³ |
| 44 | flat rail hjt-1 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 45 | flat rail hjt-2 | Wrought Stainless Steel | 18.7862 lb | 65 in ³ |
| 46 | magnet support plate hjt-1 | 6061-T6 (SS) | 205.676 lb | 2108.55 in ³ |
| 47 | slick sheet hjt-1 | Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS) | 2.32213 lb | 455.861 in ³ |

3. Load & Restraint Information

| |
|------------------|
| Restraint |
|------------------|

| | |
|--|----------------------------|
| Restraint-1 <base weldment hjt-1> | on 3 Face(s) fixed. |
| Description: | Roller pads fixed |

| Load | | |
|---|--|--------------------|
| Force-1 <magnet support plate hjt-1> | on 4 Face(s) apply normal force 3000 lb using uniform distribution | Sequential Loading |
| Description: | Magnet weight evenly distributed on pads | |
| Force-2 <flat rail hjt-1, flat rail hjt-2> | on 4 Face(s) apply normal force 1000 lb using uniform distribution | Sequential Loading |
| Description: | Hg system weight evenly distributed on sections of rail | |

4. Study Property

| Mesh Information | |
|-------------------------|------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 1.5846 in |
| Tolerance: | 0.07923 in |
| Quality: | High |
| Number of elements: | 46335 |
| Number of nodes: | 83724 |

| Solver Information | |
|---------------------------|------|
| Quality: | High |


| | |
|-----------------|---|
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 77 Fahrenheit |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------|---|----------------------------|--|
| Plot1 | VON: von Mises stress | 3.78184 psi Node: 80530 | (52.6774 in, 2.75 in, -9.22699e-007 in) | 31114.5 psi Node: 36807 | (-49 in, -1.33534 in, 0.098234 in) |

common base assy hjt-rollers-Stress-Plot1

JPEG




6. Displacement Results

| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|----------|---------|----------|
| Plot1 | URES: Resultant displacement | 0 in | (54 in, | 0.14714 | (3 in, |
| | | Node: | -1.9 in, | in | 3.875 |

| | | | | | |
|--|--|-------|--------------|----------------|---------------|
| | | 27840 | -19.5 in) | Node: 64726 | in, 19 in) |
|--|--|-------|--------------|----------------|---------------|

common base assy hjt-rollers-Displacement-Plot1

JPEG




7. Design Check Results

common base assy hjt-rollers-Design Check-Plot4

JPEG


Model name: common base assy hjt
Study name: rollers
Plot type: Design Check Plot4
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 10



common base assy hjt-rollers-Design Check-Plot7

JPEG


Model name: common base assy hjt
Study name: rollers
Plot type: Design Check Plot7
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 7



common base assy hjt-rollers-Design Check-Plot9

JPEG


Model name: common base assy hjt
Study name: rollers
Plot type: Design Check Plot9
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 1.3



common base assy hjt-rollers-Design Check-Plot6

JPEG


Model name: common base assy hjt
Study name: rollers
Plot type: Design Check Plot6
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 1.9



common base assy hjt-rollers-Design Check-Plot8


JPEG

Model name: common base assy hjt
Study name: rollers
Plot type: Design Check Plot8
Criterion: Max von Mises Stress
Factor of safety distribution: Min FOS = 1.8



common base assy hjt-rollers-Design Check-Plot10

JPEG



8. Conclusion

Localized high stress areas occur near several weld areas, but generalized stresses in the structure are well above material yield, so the baseplate assembly is considered structurally sound for the loading condition simulated.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Material name: Wrought Stainless Steel

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|-----------------|-------------|-------|------------|
| Elastic modulus | 2.9008e+007 | psi | Constant |

| | | | |
|-------------------------------|-------------|--------------|----------|
| Poisson's ratio | 0.26 | NA | Constant |
| Shear modulus | 1.1458e+007 | psi | Constant |
| Mass density | 0.28902 | lb/in^3 | Constant |
| Tensile strength | 74987 | psi | Constant |
| Yield strength | 29995 | psi | Constant |
| Thermal expansion coefficient | 6.1111e-006 | /Fahrenheit | Constant |
| Thermal conductivity | 0.00025412 | BTU/(in.s.F) | Constant |
| Specific heat | 0.11945 | Btu/(lb.F) | Constant |

Material name: Delrin 2700 NC010, Low Viscosity Acetal Copolymer (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|--|-------------|---------|------------|
| Elastic modulus | 4.2061e+005 | psi | Constant |
| Poisson's ratio | 0.3 | NA | Constant |
| Mass density | 0.0050939 | lb/in^3 | Constant |
| Tensile strength | 5903 | psi | Constant |
| Yield strength | 9137.4 | psi | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Stress Analysis of Hg System Cart

Author: V.B. Graves

Company: Oak Ridge National Laboratory

Date: May 19, 2006

1. [Introduction](#)
2. [Materials](#)
3. [Load & Restraint Information](#)
4. [Study Property](#)
5. [Stress Results](#)
6. [Displacement Results](#)
7. [Design Check Results](#)
8. [Conclusion](#)
9. [Appendix](#)

1. Introduction

A static analysis of the Hg system transport cart is performed. Simulated load of 4000 lbs was evenly distributed on two strips across the top surface of the cart. Actual assembly includes UMHW sheet and another Aluminum plate, with the loading occurring on the top plate. Simulated condition should provide conservative results since upper plate will further distribute load on lower plate. Other simplifying assumption was the removal of the cart wheel, so the axle holes were restrained.

Note:

Do not base your design decisions solely on the data presented in this report. Use this information in conjunction with experimental data and practical experience. Field testing is mandatory to validate your final design. COSMOSWorks helps you reduce your time-to-market by reducing but not eliminating field tests.

2. Materials

| No. | Part Name | Material | Mass | Volume |
|-----|----------------------|------------------------------|------------|-------------------------|
| 1 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 2 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 3 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 4 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 5 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 6 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 7 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 8 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |
| 9 | cart lower plate hjt | 6061-T6 (SS) | 104.029 lb | 1066.49 in ³ |

3. Load & Restraint Information

| Restraint | |
|---|---------------------|
| Restraint-1 <cart lower plate hjt> | on 4 Face(s) fixed. |
| Description: | Axles holes fixed. |

| Load | | |
|---|--|--------------------|
| Force-1 <cart lower plate hjt> | on 2 Face(s) apply normal force 2000 lb using uniform distribution | Sequential Loading |
| Description: | 2000 lbs on each load strip. | |

4. Study Property

| Mesh Information | |
|-------------------------|-------------|
| Mesh Type: | Solid mesh |
| Mesher Used: | Standard |
| Automatic Transition: | Off |
| Smooth Surface: | On |
| Jacobian Check: | 4 Points |
| Element Size: | 1.0218 in |
| Tolerance: | 0.051091 in |
| Quality: | High |
| Number of elements: | 9988 |
| Number of nodes: | 20458 |


| Solver Information | |
|---------------------------|--|
| Quality: | High |
| Solver Type: | FFEPlus |
| Option: | Include Thermal Effects |
| Thermal Option: | Input Temperature |
| Thermal Option: | Reference Temperature at zero strain: 25 Celsius |

5. Stress Results

| Name | Type | Min | Location | Max | Location |
|-------|-----------------------|----------------------------|--------------------------------------|--------------------------|---|
| Plot1 | VON: von Mises stress | 7.27537 psi Node: 13063 | (18.3384 in, 0 in, -1.0218 in) | 10015 psi Node: 19332 | (-15.1511 in, -0.767816 in, -15.5 in) |

cart lower plate hjt-HgSysWeight-Stress-Plot1

JPEG



6. Displacement Results


| Name | Type | Min | Location | Max | Location |
|-------|------------------------------|-------|-----------|-----------|-----------|
| Plot1 | URES: Resultant displacement | 0 in | (18.5 in, | 0.0615473 | (-5.07733 |
| | | Node: | -5.6325 | in | in, |

| | | | | | |
|--|--|-------|-------|-------|------------|
| | | 18426 | in, | Node: | 0 in, |
| | | | -15.5 | 11466 | - |
| | | | in) | | 0.00920064 |
| | | | | | in) |

cart lower plate hjt-HgSysWeight-Displacement-Plot1

JPEG

Model name: cart lower plate hjt
 Study name: HgSysWeight
 Plot type: Static displacement Plot1
 Deformation scale: 74.7528




7. Design Check Results

cart lower plate hjt-HgSysWeight-Design Check-Plot1

JPEG

Model name: cart lower plate hjt
Study name: HgSysWeight
Plot type: Design Check Plot1
Criterion : Max von Mises Stress
Factor of safety distribution: Min FOS = 4



8. Conclusion

Analysis shows minimum safety factor = 4, with maximum stress occurring in localized area near welded joint. Structure is considered structurally sound for loading condition simulated.

9. Appendix

Material name: 6061-T6 (SS)

Description:

Material Source: Library files

Material Library Name: cosmos materials

Material Model Type: Linear Elastic Isotropic

| Property Name | Value | Units | Value Type |
|---|-------------|--------------------|------------|
| Elastic modulus | 1.0008e+007 | psi | Constant |
| Poisson's ratio | 0.33 | NA | Constant |
| Shear modulus | 3.771e+006 | psi | Constant |
| Mass density | 0.097544 | lb/in ³ | Constant |
| Tensile strength | 44962 | psi | Constant |
| Yield strength | 39885 | psi | Constant |
| Thermal expansion coefficient | 1.3333e-005 | /Fahrenheit | Constant |
| Thermal conductivity | 0.0022322 | BTU/(in.s.F) | Constant |
| Specific heat | 0.21405 | Btu/(lb.F) | Constant |
| Hardening factor (0.0-1.0; 0.0=isotropic; 1.0=kinematic) | 0.85 | NA | Constant |

Appendix F. Jerome® Vapor Monitor




800-528-7411
602-470-1414
www.azic.com

Jerome® 431-X Mercury Vapor Analyzer

The Jerome 431-X mercury vapor analyzer uses a patented gold film sensor for accurate detection and measurement of toxic mercury concerns for applications such as industrial hygiene monitoring, mercury spill clean up and mercury exclusion testing. Simple, push-button operation allows users to measure mercury levels from 0.003 to 0.999 mg/m³ in just seconds.

The gold film sensor is inherently stable and selective to mercury, eliminating interferences common to ultraviolet analyzers, such as water vapor and hydrocarbons. When the sample cycle is activated, the internal pump in the 431-X draws a precise volume of air over the sensor. Mercury in the sample is absorbed and integrated by the sensor, registering it as proportional change in electrical resistance. The instrument computes the concentration of mercury in milligrams per cubic meter or nanograms, and displays the final result in the LCD readout. An improved film regeneration circuit in the 431-X makes the sensor last even longer than earlier models.

Additional accessories are available to customize the Jerome 431-X to meet individual application needs. An optional communications configuration allows data logging, computer interface, and dosimeter analysis capabilities. For data acquisition during portable surveys, a Jerome data logger plugs into the 431-X. Using Jerome Communications Software (JCS), the analyzer and data logger download recorded data to a computer for analysis, printout, and permanent record storage. The software can also program the instrument for stand-alone monitoring. If the sensor becomes saturated while the 431-X is attached to the data logger or computer, the analyzer automatically regenerates the sensor and then resumes sampling. Jerome gold coil dosimeters, used in conjunction with a low-flow pump and a communications-configured 431-X, provide time-weighted averages for personal mercury exposure. Analysis is quickly performed in-house with these reusable dosimeters. They can also be used as collection devices for applications such as gas stream analysis. An available internal option board allows auto-zeroing, DC power operation, timed regeneration, and timed sampling during prolonged, unattended sampling periods. The option board also allows external fresh air solenoid support and 4-20 mA or 0-2 V analog output. A molded hard carrying case or soft field case give added versatility and organized storage for the instrument and its accessories.



Jerome® 431-X

Mercury Vapor Analyzer



800-528-7411
602-470-1414
www.azic.com

Features:

Rugged and easy operate
Inherently stable gold film sensor
Pressure sensitive membrane switch operation
Accurate analysis of mercury vapor in seconds
Rechargeable internal battery pack for portability
Wide detection range allows for multiple applications
Automatic LCD backlight during low light conditions
Survey mode for rapid source detection of mercury vapor concentrations
Microprocessor ensures a linear response throughout the entire range of the sensor

Specifications:

| | |
|------------------------------|---|
| Resolution | 0.001 mg/m ³ |
| Detection Range | 0.003-0.999 mg/m ³ |
| Precision | 5% Relative Standard Deviation at 0.100 mg/m ³ |
| Accuracy | ±5% at 0.100 mg/m ³ |
| Response Time | 13 seconds in Sample Mode; 4 seconds in Survey Mode |
| Flow Rate | 750 cc/min |
| Environmental Range | 0-40°C, noncondensing, nonexplosive |
| Interface | RS-232 port using Jerome Communications Software |
| Dimensions | 431-X: 6" W x 13" L x 4" H / 16 cm W x 33 cm L x 10 cm H 431-XE: 7" W x 14" L x 7" H / 18 cm W x 35 cm L x 18 cm H |
| Weight | 431-X: 7 lbs / 3 kg 431-XE: 8 lbs / 3.5 kg |
| Internal Battery Pack | Rechargeable nickel-cadmium |
| Power Requirements | 100-120 V~, 50/60 Hz, 1 A or 220-240 V~, 50/60 Hz, 1 A |
| Warranty | 1 year, factory parts and labor |
| Marks | European Communities (CE) for 220-240 V~ 431-XE model only |


Options:

Data Logger to record field monitoring information
Maintenance Kit for routine maintenance and upkeep
Functional Test Kit for sensor operation verification in the field
Hard or Soft Field Carrying Case for versatile handling and additional storage
Jerome Communications Software Kit for downloading information from the data logger to a PC or for unattended, fixed-point sampling
Dosimeters to provide time-weighted averages for personal mercury exposure or gas steam analysis (reusable)
Option Board for external fresh air solenoid support, auto-zeroing, DC power operation, timed regeneration, 4-20 mA or 0-2 V analog output, and timed sampling
Calibration Check to verify low-level detection limits at 0.010 mg/m³ and 0.025 mg/m³

Applications:

| | |
|------------------------------------|---|
| Mercury Surveys and Soil Screening | Research Projects for Stack, Flue and Natural Gas |
| Spill Response | Mercury Exclusion Tests |
| Worker Safety | Monitor Disposal and Recycling of Fluorescent Lamps |
| Hazardous Waste Sites | Exhaust Duct Analysis |

Appendix G. Scavenger



SCAVENGER SERIES



HS-3000A1 Single Hose Scavenger

Capture fumes and particles at the source

Ideal for use in:

- **Soldering**
- **Small scale welding**
- **Jewelry manufacture**
- **Potting**
- **Buffing and grinding**

[Get Prices](#)



HS-3000A2 Two Hose Scavenger



Custom Hood

The Scavenger Series portable fume/particle extractors are an inexpensive solution to all small scale, yet potentially hazardous, fume and particle problems. These powerful yet quiet, fully portable systems are ideal for use in work spaces that are too small for conventional fume hoods. They can be used on the table top or wall mounted. The unit combines a 530 cfm blower with either one or two intake

scoops, each with a 5 foot heavy duty flex hose, which can be easily moved to capture the contaminant at the source. Each blower is operated with a variable speed control knob and is virtually vibration free.

Primarily designed to improve safety and hygiene in light industrial settings, the Scavenger can also be used in laboratories where a fume source can be isolated. Examples include wall mounted units to capture harmful exhaust from microwave ovens in histology labs, and spectrophotometers in analytical chemistry applications.

[Get Prices](#)

Like all Airfiltronix systems, the Scavengers can accommodate a variety of filters: charcoal, four stage dacron, aluminum, and HEPA filters, to capture broad range of chemical fumes, odors and particles - at their source.

[Get Prices](#)

SCAVENGER SERIES SPECIFICATIONS

Model No:

HS-3000A1 - Single Hose Scavenger: includes one 5" diameter hose and one tapered collector scoop.

HS-3000A2 - Double Hose Scavenger: includes two 5" diameter hoses and 2 tapered collector scoops.

Blower Dimensions: - 16" H x 12.5"D x 23.5" W

Hose: - 5" diameter heavy duty chemical resistant PVC flexible hose. Single 5 foot length for HS3000A1 and double 5 foot lengths for HS-3000A2

Standard Nozzles: - Wedge shaped Nozzles measure 9.5" D x 6.5"H, sloping to 3.5" H x 6.5" W (custom scoops and other adapters available)

Power Requirements: - 115V AC, 100 Watts, 50/60 Hz, 230V AC optional for export.

Weight: - HS-3000A1 - 37 lbs. HS-3000A2 - 43 lbs.

Noise Level: - A weighted noise level 68 dB at 1 meter

Custom Variations: - We can manufacture the scavenger series in many different configurations (i.e. wall mounted blower, mini-hood with hose attachment, unique adapter fabricated to attach to existing equipment - please call to discuss your special application).

Scavenger Options:

- Wall Mount Kit
- Additional Flex Hose 5" Diameter
- Blocked Filter Alarm Unit
- Outside Vent Adapter Kit
- Stainless Steel Cart
- Carry Handle

Airflow Performance Statistics

| Unit | HS-3000A1 | HS-3000A2 |
|------|-----------|-----------|
|------|-----------|-----------|

[Get Prices](#)

| Filters Installed | Max Airflow CFM | Face Velocity FPM | Max Airflow CFM | Face Velocity FPM |
|---------------------------|---------------------------|-----------------------------|---------------------------|-----------------------------|
| None | 173 | 1275 | 273 | 1010 |
| HEPA | 118 | 870 | 154 | 565 |
| HEPA/Dacron/.5" Carbon | 116 | 850 | 143 | 525 |
| HEPA/Dacron/2" | 94 | 690 | 110 | 405 |

| | | | | |
|--------------------|-----|------|-----|-----|
| Carbon | | | | |
| 0.5" Carbon | 156 | 1150 | 228 | 840 |
| 2" Carbon | 110 | 812 | 160 | 590 |
| 2 each - 2" Carbon | 94 | 690 | 120 | 440 |

All numbers refer to average readings taken at full blower speed

NOTE: For filter info see our [Filter Page](#)
[Get Prices](#)

[Home](#) || [Introduction](#) || [Products](#) || [What's New](#) || [Contact Us](#)

AIRFILTRONIX CORP.

154 Huron Avenue
Clifton, NJ 07013
Phone: 973.779.5577
Toll Free: 800.452.8510
Fax: 973.779.5954
airfiltron@aol.com

Web Design by:

Appendix H. Tiger-Vac® Vacuum Cleaner

**MERCURY RECOVERY VACUUM CLEANER SYSTEMS
FOR WET AND DRY RECOVERY
MRV-16**



ALL STAINLESS STEEL CONSTRUCTION

STATIC FREE AND ESD SAFE

HEPA FILTER EFFICIENCY 99.99% ON 0.3 MICRONS

MRV-16

SPECIFICATIONS:

| Models Part No | HP | 1 Phase/Volts @ 60 HZ | Amps | Vacuum Pressure at Sealed Orifice H2O | Airflow CFM/l/s |
|-------------------|----|--------------------------|------|--|--------------------|
|-------------------|----|--------------------------|------|--|--------------------|

MRV-16

| | | | | | |
|---------|-----|-----|------|------|--------|
| 110800A | 1.6 | 120 | 10.5 | 110" | 110/48 |
|---------|-----|-----|------|------|--------|

Recovery Capacity of Mercury Recovery Jar: 20 ounces (591ml)

Recovery Capacity: Dry: 5 gallons (19 litres)

Liquids: 12.5 gallons (50 litres)

Suction Orifice on all models: 1.5" (38mm)

| Models Part No | KW | 1 Phase/Volts @ 50 HZ | Amps | Vacuum Pressure at Sealed Orifice mm H2O | Airflow l/s |
|-------------------|----|--------------------------|------|---|----------------|
|-------------------|----|--------------------------|------|---|----------------|

MRV-16

| | | | | | |
|---------|------|-----|---|------|----|
| 110800B | 1.05 | 240 | 5 | 2100 | 48 |
|---------|------|-----|---|------|----|

Recovery Capacity of Mercury Recovery Jar: 591 millilitres

Recovery Capacity: Dry: 19 litres

Liquids: 50 litres


Suction Orifice : 38mm

list activated carbon and picture

Design Application

- Mercury Recovery Vacuum Cleaner System for wet and dry recovery
- All Stainless Steel Construction with an autoclavable recovery tank.
- Hour Counter
- Internal HEPA Filter 99.99% efficiency on 0.3 micron.
- Suction hose with Mercury Separator

Special Features and Specifications



Dry Recovery

Liquid Recovery

Mercury Separator

A. Mercury Separator & detachable mercury recovery jar: Separates the liquid mercury and directs it into the recovery jar. The mercury separator is made of stainless steel for excellent corrosion resistance and easy decontamination. Separator assembly includes 2 jars.

B. Hour Counter / Timer: Facilitates the measuring of the carbon filter life.

C. Floater: Cuts-off suction when recovered liquids reach capacity level.

1. Poly liner: Clear poly line (6 mil) disposable, to facilitate recovery and disposal.

2. Paper Filter Bag: Disposable paper filter bag with latex micro-liner, on micron efficiency. Facilitates recovery and disposal.

3. Double Cloth Filter: Washable, one micron efficiency.

4. HEPA Filter: 99.99% efficiency on 0.3

microns

5. Carbon Cartridge Assembly: For the

adsorption of mercury vapors and odors. Designed to completely adsorb mercury vapors for one hour of continuous exposure. After one hour of exposure the concentrations of mercury vapors will begin to rise above 0.000 mg/M³.

Once the carbon has been exposed to mercury vapors for one hour, it is the operator's responsibility to ensure that the exhaust air falls within permissible exposure limits. The recommended device is the Jerome brand mercury analyzer or other similar devices. (Not included with the vacuum cleaner.)

6. Liquid Filter: Made of polypropylene mesh. Prevents large particles from being sucked-up during liquid recovery.

More Special Features and Specifications

- All models include Suction hose with Mercury Separator
- All units include a Carbon Cartridge Assembly filled with 18 lbs (8kg) of 3mm Mersorb brand carbon for the adsorption of mercury fumes and odors.
- Noise level of vacuum cleaner at high speed is 70 dB (A) @ 6.5 ft (2m).
- EMI/RFI Shielded with electronic filter suppressor for Class B computing devices.
- Static free / ESD safe

WARNING!

Not to be used to vacuum up flammable or ignitable materials or dusts.

Do not use this vacuum cleaner in hazardous locations.

Please consult out technical representatives if an Explosion Proof / Dust Ignition Proof vacuum cleaner is needed for hazardous locations.

Appendix I. Peristaltic Pump

Peristaltic Pump Test Results

Date: Mon, 3 May 1999 16:27:45 -0400

To: gabrielta@ornl.gov, hainesjr@ornl.gov, rennichmj@ornl.gov, mcmanamytj@ornl.gov, martinsrjr@ornl.gov, taleyarkharp@ornl.gov, kims@ornl.gov, tsaic@ornl.gov, manneschmiet@ornl.gov, palmerwe1@ornl.gov, burgesstw@email.rpsd.ornl.gov, ray@email.rpsd.ornl.gov, schrock@email.rpsd.ornl.gov, scottch@ornl.gov, spampina@email.rpsd.ornl.gov

From: Van Graves <gravesvb@ornl.gov>

Subject: Mercury Pumping Results

On April 30, Phil Spampinato and myself were able to test the ability of our tubing pump to remove mercury from one of the Y-12 flasks. With the help of Eric Manneschmidt we were able to transfer mercury between containers and obtain some rough estimates of pumping rates. Some pictures of the pumping equipment are shown below, and I've included some notes we jotted down. But the bottom line is that this technique seems to be a safe, efficient, and ergonomic method of loading mercury into the TTF storage tanks.

The pumping equipment was purchased from Cole-Palmer and consists of a removable pump head mounted to a variable-speed, bi-directional drive motor. Flexible Tygon tubing is inserted in between rollers in the pump head. These rollers pinch the tubing, creating a vacuum and pulling mercury through the tube. Thus, only the tubing comes in contact with the liquid, so the pump equipment is not contaminated. In our experiment we used plastic hose clamps to connect the flexible tubing to a section of rigid stainless tubing that was used as a dip tube for the mercury flasks. The other end of the flexible tubing was left open to empty into another container; for actual loading operations it would be connected to some rigid pipe which drained into the storage tank.

In our initial tests with water we were able to achieve a maximum flow rate of approximately 0.15 liters/sec. With mercury, the best flow rate we could get was 0.03 l/s, based on rough volume and time measurements. At this flow rate we could expect to empty a flask in 75 seconds. Hence, it appears that the Hg loading operation can be accomplished in less than half of the two-week estimate envisioned for pouring the flasks.

Other items of interest:

* Due to the way the pump works, once air enters the dip tube, vacuum is lost, and any mercury remaining in the dip tube will fall back into the flask. In our experiment the leftover quantity was approximately 15 ml. Over the entire 540 flasks, this equates to less than one liter not being transferred. To keep this quantity to a

minimum, the top of the dip tube needs to be the highest point in the system. We also plan on slightly tipping the pallets to maximize the amount of mercury pulled from the flasks before suction is lost.

* When removing the dip tube from the flask, no dripping was observed. This should minimize the possibility of contaminating the exterior of any flasks or of the pallet. We plan on wiping the dip tube with cheesecloth as it's removed from each flask to further reduce the risk of drips.

* The pump has an "occlusion adjustment" that controls how tightly the pump rollers pinch the tubing and the amount vacuum created. The standard setting worked well with water but was not enough to start the mercury flow. Increasing the setting solved this problem, but it has the side effect of reducing the tubing life. Once flow is initiated the adjustment can be decreased without losing flow. Since tubing failure seems to be the worst accident envisioned we will periodically replace the tubing or move it to a different position so the rollers aren't wearing on the same tube location.

* This test was originally scheduled to be done in Rusi Taleyarkhan's lab at the Engineering Technology Division. Once the equipment was set up, we found that we were unable to remove the plug from the flask using available tools. From discussions with Y-12 personnel, many of the plugs have been put on using an impact wrench, and in addition the plugs are somewhat rusty. Removing the plugs without taking the flasks from the pallet may be the most difficult part of this process. We hope they can be removed the same way they were inserted and will try this when the mercury flasks are on site.



Figure H-1. Tube pump test setup; M & C Division fume hood.



Figure H-2. Pump under operation with mercury in the tube.

Appendix K. Material Safety Data Sheets



Material Safety Data Sheet

Print date: 04/07/2005

Version: 5

Revision date: 04/07/2005

1. COMPANY AND PRODUCT IDENTIFICATION

Product code: 014113-03 02
Product name: **QUINTOLUBRIC® 888 46**

Supplier:
Quaker Chemical Corporation
Quaker Park One
901 Hector Street
Conshohocken, PA 19428
610-832-4000
E-mail: she@quakerchem.com

Emergency telephone number:
* 24 HOUR TRANSPORTATION:
**CHEMTREC: 1-800-424-9300
703-527-3887 (Call collect outside of US)
* 24 HOUR EMERGENCY HEALTH & SAFETY:
**QUAKER CHEMICAL CORPORATION: (800) 523-7010(
Within US only)
Outside of US call (703) 527-3887

2. COMPOSITION/INFORMATION ON INGREDIENTS

HAZARDOUS COMPONENTS

This product does not contain any hazardous ingredients as defined under 29 CFR 1910.1200.

3. HAZARDS IDENTIFICATION

Emergency Overview

Mild eye irritation.
May cause skin irritation and/or dermatitis.
May cause irritation of respiratory tract.
May be harmful if swallowed.

Principle routes of exposure: Eyes, skin and inhalation.

Signal word: CAUTION

Eye contact: May cause slight irritation.

Skin contact: Substance may cause slight skin irritation.

Inhalation: Vapors and/or aerosols which may be formed at elevated temperatures may be irritating to eyes and respiratory tract.

Ingestion: Ingestion may cause gastrointestinal irritation, nausea, vomiting and diarrhoea.

Physico-chemical properties: No hazards resulting from material as supplied.

4. FIRST AID MEASURES

| | |
|--|---|
| General advice: | If symptoms persist, call a physician. INJECTION INJURY WARNING: If product is injected into or under the skin, or into any part of the body, regardless of the appearance of the wound or its size, the individual should be evaluated immediately by a physician as a surgical emergency. Even though initial symptoms from high pressure injection may be minimal or absent, early surgical treatment within the first few hours may significantly reduce the ultimate extent of the injury. |
| Eye contact: | Rinse immediately with plenty of water, also under the eyelids, for at least 15 minutes. If symptoms persist, call a physician. |
| Skin contact: | Wash off immediately with soap and plenty of water. If skin irritation persists, call a physician. |
| Ingestion: | If swallowed, seek medical advice immediately and show this container or label. Never give anything by mouth to an unconscious person. |
| Inhalation: | Move to fresh air in case of accidental inhalation of vapors. If not breathing, give artificial respiration. If breathing is difficult, give oxygen. Consult a physician. |
| Notes to physician: | Treat symptomatically. |
| Medical condition aggravated by exposure: | Dermatitis. |

5. FIRE-FIGHTING MEASURES

| | | |
|--|--|--------------------------------|
| Flash point (°C): 260 | Flash point (°F): 500 | Flash Point Method: COC |
| Flammable limits in air - upper (%): Not determined | Flammable limits in air - lower (%): Not determined | |
| Suitable extinguishing media: | Use dry chemical, CO2, water spray or `alcohol` foam. | |
| Unusual hazards: | None known | |
| Special protective equipment for fire-fighters: | As in any fire, wear self-contained breathing apparatus pressure-demand, MSHA/NIOSH (approved or equivalent) and full protective gear. | |
| Specific methods: | Water mist may be used to cool closed containers. | |

6. ACCIDENTAL RELEASE MEASURES

| | |
|-----------------------------------|--|
| Personal precautions: | Ensure adequate ventilation. |
| Environmental precautions: | Do not flush into surface water or sanitary sewer system. |
| Methods for cleaning up: | Soak up with inert absorbent material (e.g. sand, silica gel, acid binder, universal binder, sawdust). |

7. HANDLING AND STORAGE

Handling

| | |
|---|---|
| Technical measures/precautions: | Provide sufficient air exchange and/or exhaust in work rooms. |
| Safe handling advice: | In case of insufficient ventilation, wear suitable respiratory equipment. |
| Storage | |
| Technical measures/storage conditions: | Store at room temperature in the original container |
| Incompatible products: | No special restrictions on storage with other products |
| Safe storage temperature: | 40-100 ° F |
| Shelf life: | 12 months and re-evaluate |

8. EXPOSURE CONTROLS / PERSONAL PROTECTION

Engineering measures: Ensure adequate ventilation.

Personal Protective Equipment

| | |
|----------------------------------|---|
| General: | Eye Wash and Safety Shower |
| Respiratory protection: | Not required; except in case of aerosol formation. |
| Hand protection: | Neoprene gloves |
| Skin and body protection: | Usual safety precautions while handling the product will provide adequate protection against this potential effect. |
| Eye protection: | Safety glasses with side-shields. |
| Hygiene measures: | Avoid contact with skin, eyes and clothing. |



9. PHYSICAL AND CHEMICAL PROPERTIES:

| | |
|--|------------------------------|
| Physical state: | Liquid |
| Color: | Clear, Amber |
| Odour: | Mild |
| Boiling point/boiling range (°C): | >260 |
| Boiling point/range (°F): | >500 |
| Vapour pressure: | Not determined |
| Vapour density: | Not determined |
| VOC Content Product: | 0.030 lb/gal (EPA Method 24) |
| Solubility: | Insoluble |
| Evaporation rate: | Not determined |
| pH: | Not applicable |
| Flash point (°C): | 260 |
| Flash point (°F): | 500 |
| Decomposition temperature: | Not determined |
| Auto-ignition temperature: | Not determined |

| | |
|--|-------------------|
| Density @ 15.5 ° C (g/cc) : | 0.911 |
| Bulk density @ 60 ° F (lb/gal): | 7.60 |
| Partition coefficient (n-octanol/water, log Pow): | Not determined |
| Explosive properties: | |
| - upper limit: | No data available |
| - lower limit: | No data available |

10. STABILITY AND REACTIVITY

Conditions to avoid:

None known

Materials to avoid:

Strong oxidising agents

Hazardous decomposition products:

Nitrogen oxides (nox), Oxides of phosphorus, Carbon oxides, Sulphur oxides

Stability:

Stable under recommended storage conditions.

Polymerization:

Not applicable

11. TOXICOLOGICAL INFORMATION

Oral toxicity (rats): Practically non-toxic (LD50>10ml/kg). Based on testing of the product or a similar product.

Inhalation toxicity (rats): practically non-toxic (LC50>200ml/kg). Based on testing the product or a similar product.

Eye irritation (rabbits): Essentially a non-irritant (Draize score = 0). Based on testing of the product or a similar product.

Skin irritation (rabbits): Slightly irritating (Primary Irritation Index = 1.46). Based on testing of the product or a similar product.

Human Patch Skin Study: Not an irritant or a sensitizer (Modified Shelanski). Based on testing of the product or a similar product.

12. ECOLOGICAL INFORMATION

Persistence and degradability: Environmental Fate and Effects: Under the modified Sturm Test (40 CFR 796.3620), this product is readily biodegradable.

Mobility: No data available

Bioaccumulation: No data available

Ecotoxicity effects: No data available

Aquatic toxicity: Aquatic Toxicity: Acute LC/EC50 (fish) - this product is non-toxic (LC50 > 2000ppm) based on testing of this product or a similar product.

13. DISPOSAL CONSIDERATIONS

| | |
|---|---|
| Waste from residues/unused products: | Waste disposal must be in accordance with appropriate Federal, State, and local regulations. This product, if unaltered by use, may be disposed of by treatment at a permitted facility or as advised by your local hazardous waste regulatory authority. |
| Contaminated packaging: | Do not re-use empty containers |
| Methods for cleaning up: | Take up mechanically and collect in suitable container for disposal. |

14. TRANSPORT INFORMATION

U. S. DEPARTMENT OF TRANSPORTATION:

Proper shipping name: Not Regulated

Shipping Description:

TDG (CANADA):

Proper shipping name: Not Regulated

IMDG/IMO:

Proper shipping name: Not Regulated

IATA/ICAO:

Proper shipping name: Not Regulated

15. REGULATORY INFORMATION

CLASSIFICATION AND LABELING

OSHA Hazard Communication Standard: This product is considered non-hazardous under the OSHA Hazard Communication Standard.

Canada - WHMIS Classification Information: This product has been classified according to the hazard criteria of the CPR and the MSDS contains all the information required by the CPR.

Product Classification: None Required
Product Classification Graphic(s):

Component Classification Data:

Canadian National Pollution Inventory Data:

U.S. REGULATIONS:

SARA (311, 312) hazard class: This product possesses the following SARA Hazard Categories:

Immediate Health (Acute): No
Delayed Health (Chronic): No

Flammability: No
Pressure: No
Reactivity: No

RCRA Status Not Regulated

STATE REGULATIONS (RTK):

California Proposition 65 Status: No components are listed

INVENTORY STATUS:

United States TSCA - Sect. 8(b) Inventory: This product complies with TSCA

Canada DSL Inventory List - DSL Compliance has not been determined

EC No. Compliance has not been determined

16. OTHER INFORMATION

Sources of key data used to compile the data sheet: Material safety data sheets of the ingredients.

Reason for revision: This data sheet contains changes from the previous version in section(s) 4

Prepared by: Quaker Chemical Corporation -Safety, Health and Environmental Affairs Group - US

HMIS classification:

NFPA rating:

Health:
1

Health:
1

Flammability:
1

Flammability:
1

Reactivity:
0

Reactivity:
0

Personal Protection:
B

Special:
NA

* Indicates possible chronic health effect

Personal protection recommendations should be reviewed by purchasers. Workplace conditions are important factors in specifying adequate protection.

Disclaimer

This product's safety information is provided to assist our customers in assessing compliance with safety/health/environmental regulations. The information contained herein is based on data available to us and is believed to be accurate. However, no warranty of merchantability, fitness for any use, or any other warranty is expressed or implied regarding the accuracy of this data, the results to be obtained from the use thereof, or the hazards connected with the use of the product. Since the use of this product is within the exclusive control of the user, it is the user's obligation to determine the conditions for safe use of the product. Such conditions should comply with all regulations concerning the product. Quaker Chemical Corporation ("Quaker") assumes no liability for any injury or damage, direct or consequential, resulting from the use of this product unless such injury or damage is attributable to the gross negligence of Quaker.

End of Safety Data Sheet

Material Safety Data Sheet

U.S. Department of Labor
Occupational Safety and Health Administration
Form Approved OMB No. 1218-0072
This form is used to comply with
OSHA's Hazard Communication Standard,
29 CFR 1910.1200.

Product Type: Impregnated Activated Carbon - CB II

SECTION I

| | |
|--------------------------------|---|
| Barnebey Sutcliffe Corporation | Emergency Telephone Number 614-258-9501 |
| 835 North Cassady Avenue | Telephone Number for Information 614-258-9501 |
| Columbus, Ohio 43216 | Date Prepared 3/6/03 |
| | Signature of Preparer (optional) |

SECTION II - HAZARD INGREDIENTS/IDENTITY INFORMATION

| Hazardous Components (Specific Chemical Identity; Common Name(s)) | OSHA PEL | ACGIH TLV | CAS | % |
|---|-------------|-------------|-------------|--------|
| Activated Carbon | Not Defined | Not Defined | 7440-44-0 | > 75% |
| Potassium Iodide | | | 7681-11-0 | <10% |
| Triethylene Diamine | | | 280-57-9 | < 5% |
| Silver | | | 7440-22-4 | < 1.1% |
| Copper Chloride | | | 13933-17-0 | < 25% |
| Sodium Hydroxide | | | 1310-73-2 | < 8% |
| Potassium Hydroxide | | | 1310-58-3 | < 10% |
| Diammonium Molybdate | | | 27546-07-02 | < 5% |
| Nickel Chloride | | | 7718-54-9 | < 25% |
| Copper Oxide | | | 01317-38-0 | <12% |
| Phosphoric Acid | | | 7664-38-2 | < 20% |
| Sulfur | | | 7704-34-9 | < 25% |
| Iodine | | | 7553-56-2 | < 15% |
| Iron Oxide | | | 1307-37-1 | <20% |
| Sulfuric Acid | | | 7664-93-9 | <20% |
| Citric Acid | | | 77-92-9 | <20% |

SECTION III - PHYSICAL/CHEMICAL CHARACTERISTICS

| | | | |
|-------------------------|----|------------------|-----------|
| Boiling Point | NA | Specific Gravity | 0.4 – 0.9 |
| Vapor Pressure (mm Hg.) | 0 | Melting Point | NA |

| | | | |
|-------------------------|-----------------------------------|------------------|----|
| Vapor Density (AIR = 1) | Solid | Evaporation Rate | NA |
| Solubility in Water | Soluble Impregnant | | |
| Appearance and Odor | Black granules, powder or pellets | | |

SECTION IV - FIRE AND EXPLOSION HAZARD DATA

| | | | |
|--|--|-----------|-----------|
| Flash Point NA | Flammable Limits Ignition Temperature > 220 °C | LEL NA | UEL NA |
| Extinguishing Media Large volumes of water or inert gas | | | |
| Special Fire Fighting Procedures None | | | |

SECTION V - REACTIVITY DATA

| | | | |
|--|----------------|----|--|
| Stability | Unstable | | Conditions to Avoid High concentrations of organics in air will cause temperature rise due to heat of adsorption. At very high concentration levels this could cause a bed fire. High concentrations of ketones and aldehydes can cause a bed temperature rise due to adsorption and oxidation. |
| | Stable | XX | |
| Incompatibility (<i>Materials to Avoid</i>) Strong oxidizers such as ozone, oxygen, permanganate, chlorine. | | | |
| Hazardous Decomposition or Byproducts Carbon monoxide may be generated in a fire. | | | |
| Hazardous Polymerization | May Occur | | Conditions to Avoid None |
| | Will Not Occur | XX | |

SECTION VI - HEALTH HAZARD DATA

| | | | |
|---|--|------------------------------------|--|
| Route(s) of Entry: | Inhalation? Irritation of respiratory system by dust and carbon fines | Skin? May cause skin irritation | Ingestion? May irritate digestive tract |
| Health Hazards (<i>Acute and Chronic</i>) Possible eye injury from dust exposure. Effect of long term exposure to dust on respiratory system has not been defined. | | | |
| Carcinogenicity: NA | NTP? NA | IARC Monographs? NA | OSHA Regulated? NA |
| Signs and Symptoms of Exposure Irritation of eyes and respiratory system may result from exposure to carbon fines | | | |
| Medical Conditions Generally Aggravated by Exposure NA | | | |
| Emergency and First Aid Procedures For eye contact, immediately flush with copious amounts of water for at least 15 minutes and seek medical attention. For inhalation, fresh air and rest. For skin contact, wash with soap and | | | |

water. For ingestion, treat as for ingestion of impregnant.

SECTION VII - PRECAUTIONS FOR SAFE HANDLING AND USE

Steps to Be Taken in Case Material is Released or Spilled

Sweep or shovel up carbon into closed container. Discard, repackage or recycle. Report in accordance with local, state and federal regulations.

Waste Disposal Method

Dispose of carbon in accordance with local, state and federal regulations.

Precautions to Be taken in Handling and Storing

Wet activated carbon removes oxygen from air posing a hazard to workers inside carbon vessels or enclosed/confined spaces. Before entering such an area, sample air to assure sufficient oxygen supply. Use work procedures for low oxygen levels, observing all local, state and federal regulations.

SECTION VIII - CONTROL MEASURES

Respiratory Protection (*Specify Type*)

NIOSH approved particulate filter if dust is generated in handling.

| | | |
|--------------------|--|---------|
| Ventilation | Local Exhaust Recommended | Special |
| | Mechanical (<i>General</i>) Recommended | Other |

Protective Gloves

Rubber or latex gloves

Eye Protection

Safety glasses or goggles

Other Protective Clothing or Equipment

As needed.

Work/Hygienic Practices

Avoid generation of dust in handling. Avoid skin and eye contact.